

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT			1	2	1	2	1	2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>3</b>	<b>2</b>	<b>3</b>	<b>2</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 19.12.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/33KV SS Singotam	Narsaipally	33KV	Nagarkurnool	11.15	14.59	03.44	E/L & O/L	for Tree Branch Fallen on the line near Yetham cross road	Narsaipally	-
1	SDPT	Mustyala	Komuravelly	33KV	Husnabad	08.30	09.30	01.00		Tree branch fallen on line, same rectified	Komuravelly	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 19.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	kasarabada	T.K Pahad	11KV	Suryapet	08.45	10.10	01.25	E/L	Bird fallen on the 11Kv line	-
1	SDPT	Chellapur	Rajakkapet	11KV	Siddipet	04.25	10.54	06.29		B/down 11kv wire cut Lc no 22246	-
2		Dharmaram	Potharam	11KV	Husnabad	05.00	09.45	04.45		DTR Burning fallen on the Grass	-
1	RR N	Aliabad	Jaganguda	11KV	Medchal	09.00	09.45	00.45		Bird fallen on the 11KV Line at Yellamma Temple	-
1	HYD N	Raheja	Info Tech	11KV	X	18.00	20.05	02.05	EL	Cable Fault	Arranged B/F on 11KV APIIC-I fdr
1	HYD C	Chilkaiguda	44 Bus Stop	11KV	II	04.36	06.35	01.59	EL	No Visible Fault	Arranged B/F on 11KV Parsigutta fdr