

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 20.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mellavai	Revelly	11KV	Devarakonda	12.00	13.20	01.20	E/L	11 KV Jumper Cutt	-
2		Chamapur	Singaram	11KV	Bhongir	05.00	10.40	05.40	EL/OL	11 kv Insulator failed at Bhadradi well near Singaram village.	-
1	SDP	Gouravelly	Gubbadi Jangam	11KV	Husnabad	09.30	12.35	03.05		Insulator Fail	-
2		THUNKIBOLLARAM SS	THUNKIBOLLARAM	11KV	Gajwel	06.00	10.00	04.00		LT CABLE CUT	-
3		Nangnoor	Nagarajupally	11KV	Siddipet	05.20	12.00	06.40		B/D Insulator Fail Ic no. 22897	-
1	RR E	Moula-Ali	Gayathri Nagar	11KV	Sainikpuri	07.52	09.03	01.11		11Kv jumper cut at Kushaiguda Bus Depo (Artisan Raju)	-
2		Cherlapally	Rampally	11KV	Keesara	09.15	11.10	01.55		11KV Polymer Disc failed at SBM Company due to Bird fallen	-
1	HYD N	Patigadda	Zeera	11KV	V	23.08	00.40	01.32	EL,OL	I/C Cable fault at Dumping Yard & Pin Insulator flash over at Zeera	At 00:25Hrs partial loads added on 11KV H.S.P.H. fdr & remaining loads added on 11KV Hyder Basthi fdr
1	HYD S	Falaknuma	Aliyabad	11KV	III	03.57	05.20	01.23	EL,OL	Cat fallen on DTR at Shah Gouse Hotel	-----
2		Falaknuma	Fathima Nagar	11KV	III	23.15	01.58	02.43	EL,OL	I/C Cable fault at Fathima Nagar	Arranged B/F on 11KV Farooq Nagar fdr