

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	2	1	2	1	2	0	0	
	Grand Total	1082	6468	1	3	1	3	1	3	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.12.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Watpally	Medikunda	33KV	Jogipet	12.26	13.35	01.09		BD Due to Tree fallan on line	Medikunda	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 27.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Tekumatla	Rayanigudem	11KV	Suryapet	13.10	14.25	01.15	E/L	11Kv Jumper cut	-
1	MDK	Kistareddypet	Green Filed	11KV	Patncheru	09.25	12.34	03.09		BD Due to pole damage nd fallan on line	-
1	HYD S	Yakuthpura	Khan Nagar	11KV	VIII	09.37	10.48	01.11	EL	AB Cable fault at Nizam Hotel	