

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	2	1	2	1	2			
3	MDK	107	933	1		1		1				
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	4	3	4	3	4	0	0	
	Grand Total	1082	6468	3	6	3	6	3	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.12.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Madgulapally	Buggabaigudem	33KV	Miryalaguda	06.30	06.30	03.00		insulator failed	Buggabaigudem	-
1	MDK	Gummadidala	Gummadidala	33KV	Patancheru	00.00	03.30	03.30		BD due to Conductor snapped	Gummadidala	-
1	SDP	Thukkapur	Lingapur	33KV	Gajwel	04.55	08.00	03.05		BD (Jumper Cut)	Lingapur	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 28.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Gangapur	11KV	Jadcherla	09.43	11.30	01.47		11Kv Jumper Cut Near Gangapur (Vi).	-
1	NLG	Annaram	Kothagudem	11KV	Suryapet	09.30	11.30	02.00	E/L	Insulator failed	-
2		Kattangur	Duginelly	11KV	Nalgonda	12.30	13.30	01.00	E/L	Insulator failed	-
1	SDP	NACHARAM	ANATAGIRIPALLY	11KV	Gajwel	08.30	12.30	04.00		DISC FAIL	-
1	RR E	Cherlapally-I	Nagaram	11KV	Sainikpuri	09.20	10.30	01.10		End Kit failed at Snehapuri Enclave (L.Insp Kishore Raju)	-
1	HYD C	Vittalwadi	Gandhi Kuteer	11KV	II	03.44	04.57	01.13	EL,OL	No Visible Fault	-