

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3							
2	NLG	144	988		4							
3	MDK	107	933									
4	SDPT				1							
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	0	0	0	0	0	
	Grand Total	1082	6468	0	11	0	3	0	3	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.12.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 30.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Nacharam	11KV	Narayanapet	11.10	12.51	01.41		Due to HT line cut and fallen on LT	-
2		Salkarpet	Salkarpet	11KV	Narayanapet	05.35	08.05	02.30		Due to 11 KV conductor cut	-
3		Kothamolgara	Karvena	11KV	Jadcherla	03.25	07.05	03.40		11KV Jumper cut near Kothamolgara	-
1	NLG	Palem	Palem	11KV	Nalgonda	11.00	12.30	01.30	EL	Insulator failed	-
2		Kistrampally	Kurampally	11KV	Devarakonda	10.12	11.02	00.50	EL	B/D of 11 KV Jumper Cutt	-
3		Azmapur	Azmapur	11KV	Devarakonda	14.10	14.55	00.45	EL	B/D of 11 KV Insulator Failed	-
4		Yannaram	Kakkireni	11KV	Choutuppal	04.50	07.05	02.15	EL/OL	11kv pole Fallen at Agriculture wet lands Kakkireni Village	-
1	SDPT	Bekkal	Bairanpally	11KV	Husnabad	10.10	13.05	02.55		Insulator Fail	-
1	RR S	Manikoda	Friends Colony	11KV	Ibtahimbagh	16.05	18.20	02.15		11 KV Cable fail at Panchavathi	-
1	RR N	UMCC	HAL Colony	11KV	Medchal	19.35	19.55	00.20	BD	11KV Line AB Switch opened at UMCC SS(100KVA DTR Brass patti cut at Hanuman Temple,PP Nagar)	-
2		Devarayamjal	DMC	11KV	Medchal	07.40	08.40	01.00	BD	No Fault	-