

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	3	0	3	0	3	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	



TSSPDCL - LMRC / Corporate office

Date: 02.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsincherla	Yellapuram	11KV	Huzurnagar	13.30	14.40	01.10	EL	Jumper cut	-
2		Pallerla	Pallerla	11KV	Bhongir	00.00	08.20	08.20	EL	11 KV Insulator failed at Durgamma temple near Lingarajupally village.	-
3		Sangem	Sangem	11KV	Choutuppal	12.18	14.11	01.53	OL	100 kva DTR Failed Near Sangem village	-
1	RR N	Yellampet	IDA Yellampet	11KV	Medhal	12.40	13.40	01.00		Tree fallen on 11KV line at Sangam Health Care, Yellampet	-
1	RR E	Chaikripuram	Shilpa nagar	11KV	Keesara	16.51	17.50	00.59		Bird fallen on 11KV line degree collage	-
1	HYD N	Zamistanpur	Sanjeevapuram	11KV	V	12.15	13.20	01.05	EL	Sparking AB Switch at S.R Hospital	-----
1	HYD S	Falaknuma	Falaknuma UG	11KV	III	22.30	23.40	01.10	EL,OL-Rph	I/C Cable fault	Arranged B/F on 11KV Falaknuma OH fdr