

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	5	0	5	0	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Udithyal	11KV	Jadcherla	10.54	13.29	02.35		11KV Insulator Failed Near Veeranapally	-
2		Kotha Molgara	Elkicherla	11KV	Jadcherla	05.00	10.00	05.00		11KV Wire cut Near Elkicherla	-
1	NLG	Aitipamula	R.C.Puram	11KV	Nalgonda	00.00	06.30	06.30	E/L	11 KV Jumper Cut	-
2		Pallerla	Kurella	11KV	Bhongir	16.00	17.30	01.30	E/L	11Kv Insulator Failed	-
3		T Giri	Thonda	11KV	Suryapet	08.00	10.32	02.32	E/L	11Kv Insulator failed	-