

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	8	0	8	0	8	0	0	



TSSPDCL - LMRC / Corporate office

Date: 06.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Khanapur	11KV	Jadcherla	00.11	07.50	07.39		2 No poles are Damaged by Lorry at Khanapur( Vi)	-
1	NLG	Nuthankal	Yarrapahad	11KV	Suryapet	15.10	16.30	01.20	EL	Insulator failed	-
2		Garidepally	Garidepally Town	11KV	Huzurnagar	06.15	07.30	01.15	EL	Due to 11Kv line snapped	-
3		Munagala	Tadvai	11KV	Huzurnagar	11.30	13.45	02.15	EL	Due to tree branch fall on 11kv line	-
4		Bollepally	Bollepally	11KV	Bhongir	03.00	06.30	03.30	EL	11 KV Insulator Failed	-
1	MDK	Anrich Bollaram	Sulaxshana-II	11KV	Patancheru	13.50	14.31	00.41		B/D due to Jumper cut	-
1	RR S	Nanakramguda	N'Widia	11KV	Gachibowli	14.10	16.42	02.32	BD	11kv UG Cable damage at Contiental hospital	-
1	RR E	Narapally	Pravathpur	11KV	Keesara	09.30	10.40	01.10		Tree fallen on 11kv line at CPRI main road	-