

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044	1	29	1	29	1	29			
	Total	606	3055	1	40	1	40	1	40	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		4		4		4			
3	MDK	107	933	1		1		1				
4	SDPT			1	11	1	11	1	11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	16	4	16	4	16	0	0	
	Grand Total	1082	6468	5	56	5	56	5	56	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Maddur	33kv	Narayanapet	10.00	10.55	00.55	E/L	11KV Line Touched the 33KV Line NEAR 132KV SS		-
2		Wanaparthy	Narsaipally	33kv	Wanaparthy	07.38	11.25	03.47	O/L	33KV Jumper Cut near 132KV SS		-
1	MDK	Gummadidala	Jinnaram	33kv	Patancheru	19.57	22.05	02.08		BD Due to Insulator fail Near Veerabhadra temple		-
1	SDPT	Husnabad	Katkoor	33kv	Husnabad	16.05	23.59	07.54		Heavy gale and wind		-
1	HYD S	220KV Ch' Gutta	Arundathi colony	33kv	Asmangadh	02.18	02.30	00.12	OL	Cable damaged by GHMC near Owasi Hospital		Loads transferred onto 220KV Ch' Gutta - C.R.P.F

TSSPDCL - LMRC / Corporate office

Date: 08.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	KothaMolgara	Madigatla	11kv	Jadcherla	10.30	13.00	02.30		11KV Wire cut near Madigatla	-
1	NLG	Dirsincherla	Yellapuram	11kv	Huzurnagar	14.30	16.55	02.25	EL	Due to 11Kv Jumper cutted	-
2		Mattmapally	Lift	11kv	Huzurnagar	04.50	07.45	02.55	EL	Due to 11Kv Insulator failure	-
3		Gurraladandi	Jampally	11kv	Bhongiri	06.15	09.24	03.09	EL	11 Disc Failed at Sathireddy well Near Jampally Village.	-
4		Mothkur	Mothkur rural	11kv	Bhongiri	06.35	10.30	03.55	EL	SS-4 near 11kv Line sanpped	-
1	SDPT	Potharam	Nagaram	11kv	Siddipet	11.55	13.15	01.20		Heavy gale and wind	-
2		Pandilla	Pandilla Rural	11kv	Siddipet	12.00	23.59	11.59		Heavy gale and wind (3-ph)	
3		Gandipally	Nandaram	11kv	Siddipet	16.55	23.59	07.04		Heavy gale and wind (3-ph)	
4		Chityala	Dhommata	11kv	Siddipet	07.30	08.00	00.30		Line cut	
5			Thadoor	11kv	Siddipet	18.10	20.05	01.55		Disk fail	
6		Dhommata	Arjunpatla	11kv	Siddipet	17.10	23.59	06.49		Heavy gale and wind (3-ph)	
7		Akkannapet	Akkannapet rural	11kv	Siddipet	19.10	20.15	01.05		Heavy gale and wind	
8		Akkannapet	Fakkimayakthanda	11kv	Siddipet	16.45	23.59	07.14		Heavy gale and wind (3-ph)	
9		Gagillapur	Vallampatla	11kv	Husnabad	18.20	20.20	02.00		Heavy gale and wind	
10		Komuravelli	Kistampet	11kv	Husnabad	18.10	20.30	02.20		Jumper cut	
11		Gurjakunta	Vechareni	11kv	Husnabad	18.35	19.40	01.05		Jumper cut	-
1	RR N	GP Pally	Neighbourhood	11kv	Medchal	03.50	05.35	01.45		11KV Conductor Snapped and replaced at CM Prakash Rao Thota,Laxmi Nagar	-
2		ICICI	ICICI	11kv	Medchal	14.20	17.50	03.30		UG Cable failed at IKP	-
3		Town Medchal	NGOs Colony	11kv	Medchal	17.50	18.59	01.09		11KV Pin Insulator failed at Swetha Hospital	-
1	RR E	Street no 8	Ravinder nagar	11kv	Habsiguda	20.56	23.00	02.04		Kite fallen on 11kv line at Rajarajeshwari Appt ravindernagar	-
2		Street no 8	Green hills	11kv	Habsiguda	20.57	22.36	01.39		Pin insulaotr fail at Sri chaitaniya school street no 8	-
3		Nacharam	Stallen tyers	11kv	Habsiguda	21.14	21.59	00.45		Tripped on EL/OL due to 11KV jumper cut at Arow lab Industries	-
4		Nacharam	Voith turbo	11kv	Habsiguda	20.58	21.50	00.52		Tripped on EL/OL due to 11KV Line cut of Voith Turbo industries	-
5		Boduppall	Surya hills	11kv	Habsiguda	21.50	22.55	01.05		11KV Pin Insulator fail at Hema nagar water tank	-
6		Malkajgiri	IN Nagar	11kv	Sainikpuri	20.58	21.45	00.47		Tree branches fallen on 11Kv line at Sai Deepthi Gopal Nagar (AE/OP)	-
7		Moula-Ali	Venkateshwar Nagar	11kv	Sainikpuri	20.45	21.45	01.00		Ground petrolling done but no visible fault found	-
8		P&T colony	Chnegicherla	11kv	Keesara	21.05	21.40	00.35		Tripped on EL/OL & Insulaotr fail Kamala nagar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Addagutta	Addagutta	11kv	C-VI	20.51	22.02	01.11	OL-Rph	No Visible fault (due to Rain)	----
2		Gymkhana	Picket	11kv	C-VI	20.54	22.37	01.43	EL,OL	No Visible fault (due to Rain)	Arranged B/F on 11KV LIC fdr
3		Seethaphal Mandi	Srinivasa Nagar Colony	11kv	V	20.55	22.40	01.45	EL	No Visible fault (due to Rain)	----
4		Patigadda	Sindhi Colony	11kv	V	20.45	22.55	02.10	EL,OL	2No DTR kept off at Sindhi Colony	----
5		Marredpally	Railway Colony	11kv	C-VI	21.35	22.45	01.10	EL,OL	Auto recloser fault near SS	----
6		Addagutta	Ambedkar Nagar	11kv	C-VI	21.10	23.02	01.52	EL	Kite stick fault at Ambedkar Nagar	----
7		Bowenpally	Ferozeguda	11kv	VI	20.50	21.55	01.05	EL	No Visible fault (due to Rain)	----
8		Monda Market	Palika Bazar	11kv	V	20.45	23.35	02.50	EL	Disc Insulator flash over at Palika Bazar	----
9		Chilkaiguda	Pragatools	11kv	V	20.50	23.36	02.46	EL,OL	No Visible fault (due to Rain)	----
10		Addagutta	Addagutta	11kv	C-VI	22.24	23.38	01.14	OL	Tree Branches fallen on lines at R.R.Apts	----
11		Macha Bollaram	Reddy Enclave	11kv	C-VI	21.36	00.00	02.24	EL,OL	Tree Branches fallen on lines at Madhura Enclave	----
12		Clock Tower	Natraj	11kv	V	21.14	00.00	02.46	EL	Insulator flash over at Navakethan Building	----
13		Hakimpet	Risala Bazar	11kv	C-VI	22.25	00.05	01.40	All Indication	No Visible fault (due to Rain)	----
14		Macha Bollaram	Krishna Nagar	11kv	C-VI	23.08	00.50	01.42	OL	AB Cable fault at Gas Godown	----
1	HYD S	Salarjung	Purani Haveli	11kv	III	02.10	03.45	01.35	EL	Cable fault & Lines Twisted at Miralam Mandi	3:05 Hrs partial fdr charged, partial fdr B/F given on 11KV Darulshifa fdr
2		Aliyabad	Police Quarters	11kv	III	21.10	22.20	01.10	EL	No Visible fault (due to Rain)	----
3		Devibagh	Bandalguda	11kv	III	21.32	22.50	01.18	EL,OL	No Visible fault (due to Rain)	----
4		Petlaburz	Sha Gunj	11kv	III	21.40	23.05	01.25	EL,OL	No Visible fault (due to Rain)	----
5		Kandikal Gate	G.M.Chowni	11kv	III	21.40	23.05	01.25	EL,OL	No Visible fault (due to Rain)	----
6		Aliyabad	Sattar Bagh	11kv	III	21.40	23.14	01.34	EL	No Visible fault (due to Rain)	----
7		Miralam	Jahanuma	11kv	III	21.20	23.25	02.05	All Indication	AB Cable fault at Rahamath Nagar	----
8		Miralam	Teegala Kunta	11kv	III	21.35	23.30	01.55	EL,OL	Kite stick fault at Rahamath Nagar	----
9		Devibagh	Rama Talkies	11kv	III	21.35	23.20	01.45	EL,OL	Bird fault at Palamur Road	----
10		Arundhathi Colony	Neelam Centre	11kv	III	21.58	00.20	02.22	EL	UG Cable End kit failed at Bambay Colony	----
11		Falaknuma	Ravindra Naik Nagar	11kv	III	22.37	00.25	01.48	EL	RMU End Kit failed at Ravindra Naik Nagar	----
1	HYD C	Golnaka	Shivalayam	11kv	II	20.56	22.13	01.17	EL,OL	Lines Twisted at D-Mart	
2		Durga Nagar	Prem Nagar	11kv	II	21.04	22.50	01.46	EL,OL	Pin Insulator flash over at Pochamma Temple	
3		Narayanagdua	Chikkad Pally	11kv	II	20.45	22.55	02.10		Insulator flash over at Lalitha Mansion	
4		Chilkaiguda	Parsi Gutta	11kv	II	20.48	23.20	02.32	EL,OL	Disc Insulator flash over at Hanuman Temple	