

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	7	2	7	2	7	0	0	
	Grand Total	1082	6468	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/132KV SS Palkonda	Kothamolgera	33KV	Mahabubnagar	02.15	02.45	00.30	E/L	Insulator Failed Near Gopulapur(V)	Kothamolgera	Alternate supply arranged From 132KV SS Ghanpur at 02:45Hrs.
1	MDK	Gummadidala	GPSS-I	33KV	Patancheru	04.55	06.35	01.40		B/D Due to Insulator Failure	GPSS-I	-

TSSPDCL - LMRC / Corporate office

Date: 10.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Madigatla	11KV	Jadcherla	07.05	08.50	01.45		Due to Tree Fallen on the 11 KV line Near Madigatla(V)	-
1	NLG	Dirsincherla	Yellapuram	11KV	Huzurnagar	09.10	12.10	03.00	EL	Due to 11kv line cutted	-
2		Alingapuram	Channaipalem	11KV	Huzurnagar	06.05	09.10	03.05	EL	Due to 11kv Jumper cutted	-
3		Anantharam	Hanmapur	11KV	Bhongir	05.00	09.30	04.30	EL	11kv Insulator Failed	-
4		Bollepally	Jampally	11KV	Bhongir	04.00	08.30	04.30	EL	11kv Disc Failed	-
5		Paladugu	Paladugu	11KV	Bhongir	08.30	10.30	02.00	EL	11kv Insulator Failed	-
1	MDK	Pati	My Home	11KV	Patancheru	14.05	14.45	00.40		B/D due to Conductor Snapped	-