

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1						1		1 No. 33KV Still
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	0	5	0	5	1	0	
	Grand Total	1082	6468	1	7	0	7	0	7	1	0	

TSSPDCL - LMRC / Corporate office

Date: 12.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	132 KV SS Kothur	Natco Pharma	33KV	Shadnagar	22.40			E/L			

TSSPDCL - LMRC / Corporate office

Date: 12.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nemmani	Melakunta	11KV	Nalgonda	8:00	9:50	1:50	E/L	11 KV Line jumper cut	No
2		Chandampeta	Chitryala	11KV	Devarakonda	09.10	11.20	02.10	E/L	11 KV Line cut	No
3		Angadipeta	P.A.Pally rural	11KV	Devarakonda	06.55	11.48	04.53	E/L	11 KV Conductor snpped	No
4		Mothkur	Mothkur town	11KV	Bhongir	14.15	15.20	01.05	EL	11 KV Insulator failed at Boys hostel near Mothkur town	No
5		Varkatpally	Gokaram	11KV	Choutuppal	4:50	7:50	3:00	EL	16 KVA DTR failed & 11 KV Line snapped near Gokaram village.	No
1	RR N	Aleap	Dr Colony	11KV	Jeedimetla	2:30	3:40	1:10	EL&OL	11KV End Kit failure near dollar homes Dr Colony	No
2		Jagathgiringutta	Jagathgiringutta	11KV	Medchal	19.15	19.45	00.30		100KVA DTR AB Switch opened at Anjaya nagar	No