

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	3	2	3	2	3	0	0	
	Grand Total	1082	6468	2	6	2	6	2	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	132 KV SS Kothur	Natco Pharma	33KV	Mahabubnagar	22.40 (12.02.20)	13.35 (13.02.20)	14.55	E/L	For Cable Kit Failed & Replacement Near Old NH	Natco Pharma	No
2		132 KV SS Kothur	Natco Chemical	33KV	Mahabubnagar	02.40	13.35	10.55	E/L	For Cable Kit Failed & Replacement Near Old NH	Natco Chemical	No

TSSPDCL - LMRC / Corporate office

Date: 13.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Reddygudem	Kothagudem	11KV	Suryapet	10.15	11.20	01.05	E/L	Pin Insulator flashover	-
2		Ambala	Ambala	11KV	Bhongir	14.40	14.30	01.50	E/L	11KV Line sanpped	-
3		Choutuppal	Chinnakondur	11KV	Choutuppal	05.15	14.55	09.45	E/L	11KV Line sanpped	-
1	RR S	L&T	PJR Nagar	11KV	Gachibowli	13.40	16.28	02.48		11kv Pin-insulator failed at Hero honda Showroom and 11kv Disk failed at sai baba temple, Telecom Nagar	-
2		Lodha	D-Mart	11KV	Kondapur	04.10	05.10	01.00		HIB AB-Cable failed at D-Mart	-
1	RR N	Jeedimetla SS I	JETL	11KV	Jeedimetla	17.20	18.35	01.15	BD	11KV AB Cable failure Substation outside	-