

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Ponnakal	Ponnakal	11KV	Jadcherla	09.30	10.30	01.00		11KV Wire cut & 11KV Insulator Failure Near Ponnakal (V)	-
2		Kothamolgara	Maddigatla	11KV	Jadcherla	06.30	12.05	05.35		11KV insulator Failure Near Nalla Gutta Side	-
1	NLG	Shaligouraram	Kondaram	11KV	Nalgonda	08.10	13.05	04.55	EL	11KV Insulator failed at SS-3	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	05.55	08.30	02.35	EL	11KV jumper cut	-
3		Nuthankal	Chilpakuntla	11KV	Suryapet	14.30	16.45	02.15	E/L	Line cut	-
4		Karivirala	Ramchandrapuram	11KV	Huzurnagar	15.05	16.40	01.35	EL	Due to 11KV line Snapped	-
5		Mukundapuram	Somaram	11KV	Huzurnagar	11.35	13.35	02.00	EL	Due to 11KV Jumper cut	-
6		Alair	Ch.Kandukur	11KV	Bhongir	04.00	09.30	05.30	EL/OL	11kv Line snapped near Ch.Kandukur Village	-
1	RR N	Dp Pally SS II	Indo fab	11KV	Jeedimetla	09.10	10.40	01.30	EL	11KV Line petrolling no visabul falt	-
1	HYD N	Kalyan Nagar	State Home	11KV	Banjarahills	08.26	10.40	02.14	EL	Relay fault at SS & Jumper cut at Community Hall (partial fdr charged at 8:29Hrs)	Arranged B/F on 11KV Madhura Nagar & 11KV Yousufguda fdrs