

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	3	0	3	0	3	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-

TSSPDCL - LMRC / Corporate office

Date: 15.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mukundapuram	Somaram	11kv	Huzurnagar	03.45	08.20	04.35	E/L	11KV jumper cut	-
2		R.N.Palem	Nakkagudem	11kv	Huzurnagar	13.02	15.02	02.00	E/L	11KV jumper cut and touched to Channel	-
3		Mothkur	Areygudem	11kv	Bhongir	10.15	12.30	02.15	E/L	11kv Line Snapeed & 11kv Insulator Failed near Aregudem (V)	-
1	RR E	Sainikpuri	Kalyan Garden	11kv	Sainikpuri	13.52	14.35	00.43		Bird fallen on 11Kv line at Kalyan Garden (AE/Yapral)	-
1	HYD C	Golnaka	Haraspenta	11kv	Azamabad	19.21	23.15	03.54	OL	RMU & Cable fault at Good shed	Arranged B/F on 11KV Prabath fdr
2		Golnaka	Shivalayam	11kv	Azamabad	20.14	21.44	01.30	EL,OL	Cable fault at Tulasi Nagar	Arranged B/F on 11KV Tulasi Nagar fdr
3		Industrial Area	Azamabad Key SS	11kv	Azamabad	20.00	21.45	01.45	EL,OL	Cable fault	Arranged B/F on 11KV Golconda X Road fdr