

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1		1		1				
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 16.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanpet	07.20	10.15	02.55	E/L	33KV Line Phase Phase at Mominpoor	Vepoor	-
1	HYD C	132KV Erragadda	Erramanzil (Idle)	33KV	H' Sagar	16.46	18.04	01.18	OL-Bph	33KV End Kit failed at 33/11KV Yellareddyguda SS (Tapping Line)	Erramanzil (Idle)	-

## TSSPDCL - LMRC / Corporate office

Date: 16.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palakeedu	Palakeedu agl	11KV	Huzurnagar	08.27	11.25	02.58	EL	Due to 11Kv Disk Failure	-
2		Bibinagar	Raghavapur	11KV	Bhongir	06.00	09.55	03.55	OL	11 kv Pole( 9.1) Dammaged Near Rahimkhanguda village	-
3		Laxmapuram	Laxmapuram	11KV	Choutuppal	08.40	11.30	02.50	OL	11 kv Line snapped at Market yard Near Laxmapuram Village	-
1	RR N	Bachupally	Nizampet	11KV	Kukatpally	05.30	06.30	01.00	EL/OL	11kv Pole Daimage At Nbizampet	-
1	RR E	Cherlapally-I	Nagaram	11KV	Sainikpuri	08.40	09.30	00.50		Bird fallen on 11Kv line at Open Jail (AE/OP)	-