

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	9	0	9	0	9	0	0	



TSSPDCL - LMRC / Corporate office

Date: 20.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thungathurthy	Vempaty	11KV	Suryapet	13.50	15.40	01.50	E/L	Insulator failed	-
2		Repala	Narsimulagduem	11KV	Huzurnagar	07.50	10.05	02.25	EL	11 KV Insulator failed	-
3		Gurraladandi	Raipad	11KV	Bhongir	05.00	08.00	03.00	EL	11 kv Line snapped at Mamidithota Near Raipad thanda	-
4		Motakondur	Motakondur Agl	11KV	Bhongir	10.00	10.40	00.40	EL	11 kv Line snapped near Motakondur village	-
1	MDK	SOL	SOL	11KV	Patancheru	11.18	11.48	00.30		BD due to 11KV line cut	-
1	RR N	Chintal	Surya Nagar	11KV	Medchal	17.10	18.50	01.40	BD	11KV Pole damaged by Lorry at Ramreddy Nagar	-
1	RR E	Vayupuri	GK Nagar	11KV	Sainikpuri	07.30	09.20	01.50		11Kv Disk failed at Sharda Hospital (LM Srinivas)	-
2		Narapally	P.Singaram	11KV	Keesara	12.40	13.50	01.10		Pin insulator fail at Venkatadri township	-
1	HYD S	Devibagh	Shalimar	11KV	Charminar	19.32	20.55	01.23	EL,OL-Bph	I/C Cable fault	Arranged B/f on 11KV Puranapool feeder