

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kothur	Sangem	33KV	Shadnagar	16.15	18.05	01.50	E/L	R Phase Jumper Cut Near 132KV SS Kothur	Sangem	-

TSSPDCL - LMRC / Corporate office

Date: 24.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Siripuram	Siripuram	11KV	Huzurnagar	09.35	10.55	01.20	EL	Due to 11Kv Jumper cutted	-
2		Karivirala	Ramchandrapuram	11KV	Huzurnagar	07.00	09.50	02.50	EL	Due to Tree branch fall on 11Kv line	-
3		Narketpally	M.Yedavelly	11KV	Nalgonda	09.16	10.26	01.10	EL	Due to 11Kv Jumper cut	-
1	RR N	Vijayanagaar	Jayanagar	11KV	Kukatpally	12.50	14.15	01.25	BD	11kv endkit failure at Navodaya colony	-
2		UMCC	Mahadevpuram	11KV	Medchal	11.58	12.24	00.26	BD	11KV Line AB Switch opened at Yandamuri Layout (11KV Jumper cut)	-
3		ICICI	Adama	11KV	Medchal	00.05	06.25	06.20	BD	11KV Jumper cut and Replaced at Sai Labs Company	-
1	RR E	P&T colony	Medipally	11KV	Keesara	12.10	13.45	01.35		11KV Snapped at Panchavathi colony	-
1	HYD N	Prashanth Nagar	Prashanth Nagar	11KV	VI	18.20	19.35	01.15	OL-Rph	Twisted lines & Tree branches fallen on lines at Ayyana Building	-
2		Vasanthapuri	Sripuri Colony	11KV	V	23.17	01.15	01.58	EL	No Visible fault	Arranged B/F on 11KV Shanti Nagar feeder & 11KV Lalapet feeder