

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988									
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	0	1	0	1	0	0	0	
	Grand Total	1082	6468	1	3	1	3	1	3	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Ghanapur	33KV	Mahabubnagar	13.36	13.48	00.12	E/L&O/L	Due to Heavy Spark & sound	Ghanapur	Alternate Supply Arranged from 220KV SS Palkonda at 13:48Hrs

TSSPDCL - LMRC / Corporate office

Date: 25.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Chintal	Surya Nagar	11KV	Medchal	15:30	16:30	1:00		AB Cable damaged at Papaiah Nagar	Alternate supply arranged from Padma Nagar feeder
2		UMCC	Gajularamaram	11KV	Medchal	17.30	19.40	02.10		11KV Breaker Problem in SS	No
3		Subhash Nagar	Jairam Nagar	11KV	Medchal	06.17	06.58	00.41		11KV Conductor snapped at Adharsha Bank	No