

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	0	1	0	1	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	1	1	1	1	1	0	0	
	Grand Total	1082	6468	2	1	2	1	2	1	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33KV	Mahabubnagar	07.55	11.57	04.02	E/L&O/L	33KV Y Phase Jumper Cut at Railway Track	Hanwada	No
1	HYD N	132KV Gunrock	Macha Bollaram	33KV	Nehru Ngr	11.25	11.31	00.06	EL	Cable fault at Narthaki Theatre, Lothkunta	Macha Bollaram	Loads transferred onto 132KV Gunrock SS via 33KV Hakimpet fdr

TSSPDCL - LMRC / Corporate office

Date: 26.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B.Chandupatla	Pandya thanda	11KV	Suryapet	3:30	6:50	3:20	E/L	Conductor snapped	No
2		Bollepally	Jampally	11KV	Bhongiri	07.20	08.25	01.05	EL/OL	11KV Line snapped	No
3		Mothkur	Kondagadapa	11KV	Bhongiri	11.30	17.00	05.30	EL/OL	11KV Insulator failed near Mothkur Village	No