

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	2	1	2	1	2	0	0	
	Grand Total	1082	6468	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Bollaram - II	33KV	Patancheru	22.30	05.30	07.00		BD due to Conductor snapped & Disk Insulator failed		-

TSSPDCL - LMRC / Corporate office

Date: 27.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsenapally	Miryala	11KV	Suryapet	13.25	14.35	01.10	E/L	Tree branch fallen	-
2		Alingapuram	Raghavapuram	11KV	Huzurnagar	13.05	16.05	03.00	EL	Due to 11Kv Line Cutted	-
1	RR N	Athiwelly	Somaram	11KV	Medchal	08.20	09.30	01.10	BD	11KV Pole damaged by Lorry at Rekula Bavi,Athiwelly	-
2		Nuthankal	Bharathi	11KV	Medchal	16.50	17.35	00.45	BD	11KV Line cut and replaced at Rice Mill ,Nuthankal	-
1	HYD C	Hussain Sagar	Fathe Maidan	11KV	Saifabad	19.33	21.05	01.32	All Indication	No Visible Fault (partial fdr charged at 20:16Hrs)	-