

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	2	4	2	4	2	4			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.02.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Bibinagar	Bollepally	33KV	Bhongir	07.05	10.15	03.10		33 KV Jumper snapped		-
2		Ramannapet	Yallanki	33KV	Choutuppal	07.35	10.10	02.35		33kv Jumper Sanpped		-

## TSSPDCL - LMRC / Corporate office

Date: 28.02.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pomal	Puttonipally	11KV	Jadcherla	11.00	15.00	04.00		11KV Wire cut near Puttonipally	-
1	NLG	Ravulapally	Kukkadam	11KV	Suryapet	12.30	15.00	02.30	E/L	Jumper cut	-
2		Dircincherilla	Yellapuram	11KV	Huzurnagar	04.20	07.30	03.10	E/L	11 Kv jumpet cut	-
3		Chada	Katepally	11KV	Bhongir	02.00	09.00	07.00	E/L	11 kv Line snapped	-
4		Puligilla	Kanchanpaly	11KV	Choutuppal	06.40	08.40	02.00	E/L	100kv DTR Failed	-
1	MDK	Bollaram - I	Arobindo	11KV	Patancheru	18.30	19.35	01.05		B/D due to Conductor snapped	-
1	HYD N	Prashanth Nagar	Shakthipuram	11KV	Bowenpally	11.20	12.30	01.10	EL	Cable damaged at IDA Kukatpally	-