

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044	1	7	1	7	1	7			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>15</b>	<b>1</b>	<b>15</b>	<b>1</b>	<b>15</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT			2	2	2	2	2	2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>20</b>	<b>3</b>	<b>20</b>	<b>3</b>	<b>20</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 01.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Mustyala	Komuravelly	33KV	Husnabad	13:25	14:40	1:15		Jumper cut	Mustyala	No
2		Palamakula	Baddipadaga	33KV	Siddipet	14.35	16.05	01.30		33KV Line touched to 'V' Cross arm	Palamakula	No
1	HYD S	220KV Osm.University	Zamistanpur	33KV	Chilkaiguda	00.36	00.46	00.10	EL,OL	Old Joint failed near SS	Zamistanpur	Loads transferred onto 132KV Chilkaiguda SS

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Badepally	Burgupally	11KV	Jadcherla	12.27	14.34	02.07		11 KV Jumper cut near at Aloor Village	No
1	NLG	Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	12:50	15:35	2:45	E/L	11KV Jumper cut	No
2		Aitipamula	Gangadevigudem	11KV	Nalgonda	05.00	10.20	05.20	E/L	11KV Jumper cut	No
1	SDPT	Koheda	Cannal	11KV	Husnabad	4:00	17:40	13:40		11KV Jumper cut	No
2		Nagapuri	Gandikunta	11KV	Husnabad	11.30	13.30	02.00		11KV Jumper cut	No
1	RR N	Medicity	Pudur	11KV	Medchal	18:30	19:30	1:00		11KV Pin insulator failed at Pudur	No
1	RR E	NGRI	Scientist Colony	11KV	Habsiguda	17:22	18:26	1:04		Tree branches fallen on 11KV line near Hanuman Temple at HBG Main Road	No
2		Polytechnic	Vishal	11KV	Habsiguda	17.42	19.42	02.00		11KV Disc failed & replaced near TV Studio Gate	No
3		IICT	Nacharam	11KV	Habsiguda	17.30	18.32	01.02		Due to Inetrnet Cable fired & touched to 11KV Line near RS Plaza at Karthikeya Nagar	No
4		Ramanthapur	Gokhale Nagar	11KV	Habsiguda	17.20	19.00	01.40		11KV Disc failed & replaced near Matrix Hospital at Ramanthapur Main Road	No
5		Kushaiguda	Sriram Nagar	11KV	Sainikpuri	08.00	08.40	00.40		11Kv pole erection at Sriram Nagar Bus Stop due to AB Switch open & 11Kv Pole dash to four wheeler	No
6		NN Colony	Jai Jawan	11KV	Sainikpuri	18.30	19.05	00.35		Tree branches fallen on 11Kv line at Ashok Manoj Nagar (Artisan Yadagiri)	No
7		Moula-Ali	Venkateshwar Nagar	11KV	Sainikpuri	17:42	18:38	0:56		11Kv Post off Insulator failed at Venkateshwar Nagar Colony	No
1	HYD N	Chilkaiguda	Dandu Pentaiah	11KV	V	17.25	18.35	01.10	EL,OL	AB Cable fault at Sai Geetha Apts	No
2		Vasanthapuri	Sheshapadu	11KV	V	17:25	19:37	2:12	EL	Disc Insulator flash over at Railway Quarters	No
1	HYD S	Kandikal Gate	G.M.Chowni	11KV	III	07.55	09.30	01.35	EL,OL	Faulty loads of 11KV Chatrinaka feeder	No
2		Attapur	N.M.Guda OH	11KV	III	16:55	18:10	1:15	EL,OL	Disc Insulator flash over at Hanuman Mandir	No
1	HYD C	Industrial Area	Mother Dairy	11KV	II	17.22	19.05	01.43	EL,OL	Tree branches on lines at Mother School	Arrnaged B/F on 11KV Ram Nagar fdr
2		Lumbinipark	Avanathi Nagar	11KV	I	17.41	19.20	01.39	EL,OL-Rph	No Visible Fault	No
3		Jawahar Nagar	Balaji Indraprastha	11KV	I	17.30	19.05	01.35	EL,OL-Rph	Lightening Arrestor failed	No