

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		4		4		4			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Buchinelly	33KV	Zaheerabad	11:35	14:15	2:40		Tree branch fallen on the line	Buchinelly	No

TSSPDCL - LMRC / Corporate office

Date: 08.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Burgupally	11KV	Jadcherla	05.45	06.47	01.02		DTR Bus bar failed near Aloor(v)	No
2		Kollur	Kollur	11KV	Jadcherla	14.40	15.30	00.50		11KV Jumper cut near Kollur	No
1	NLG	Katangur	Mallaram	11KV	Nalgonda	3:00	6:00	3:00	EL	11KV Line jumper cut	No
2		P.D.Pally	P.D.Pally	11KV	Miryalguda	08.10	10.51	02.41	EL	Conductor snapped	No
3		Indl.Estate	Bibigudem Express	11KV	Suryapet	06.00	08.30	02.30	EL	Conductor snapped	No
4		Garidepally	Appannapet	11KV	Huzurnagar	12.45	14.20	01.35	EL	11KV Line snapped	No
1	MDK	Bonthapally	Sai Baba	11KV	Patancheru	15:18	16:05	0:47		Jumper cut	No
1	HYD S	Salarjung	Salarjung Museum	11KV	III	04.55	08.45	03.50	All Indication	33Nos Jumpers damaged in Salarjung Museum	No
1	HYD C	Lumbini Park	Avanthi Nagar	11KV	I	12.38	14.26	01.48	All Indication	No visible fault	Arranged B/F on 11KV A.P.Turism fdr
2		Vittalwadi	Commissioner Office	11KV	I	17.05	18.10	01.05	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Nizam College fdr