

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 12.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	Narayanapet	06.45	08.40	01.55	O/L	No Visuble Fault	Koilkonda Water Grid	-
2		Singotam	Narsaipally	33KV	Wanaparthi	08.45	12.08	03.23	E/L&O/L	33KVJumper Cut & Connecting purpose	Narsaipally	-

## TSSPDCL - LMRC / Corporate office

Date: 12.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Keethavarigudem	Laxmipuram	11KV	Huzurnagar	07.00	09.00	02.00	O/L	11Kv jumper cut	-
2		N.B.Gudem	Redlakunta	11KV	Huzurnagar	23.30	01.30	02.00	E/L	11Kv line snapped	-
3		Solipet	Peraram	11KV	Bhongir	10.05	11.10	01.05	EL/OL	11kv Line Sanpped near Thimmapur (V)	-
4		Solipet	Peraram	11KV	Bhongir	12.20	14.25	02.05	EL/OL	SS-11 Near 11kv Line sanpped	-
1	RR N	HMT	Venkanna Hills	11KV	Medchal	13.30	15.10	01.40	BD	No Fault	-
2		Shameerpet	Nalsar	11KV	Medchal	05.50	07.00	01.10	BD	11KV Pole damaged by Unkown Vehicle at BSNL Office	-
1	HYD S	Panjesha	Gulzarhouse	11KV	Charminar	15.00	16.11	01.11	EL,OL	Breaker problem at SS	Partial loads charged (12/60Amp) & remaining loads added on 11KV Telephone Exchange fdr