

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Gird	33kv	Narayanapet	09.55	11.30	01.35	EL	CT Problem	Koilkonda Water Gird	-

TSSPDCL - LMRC / Corporate office

Date: 13.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narkatpally	Mandra	11kv	Nalgonda	13.00	14.50	01.50	E/L	11KV Jumper cut	-
2		Pamanagundla	Ismailpally	11kv	Nalgonda	06.23	10.21	03.58	E/L	Parrot died on 11KV line	-
3		Pottichelma	Chalapurthy	11kv	Miryalaguda	13.00	14.25	01.25	E/L	Jumper cut	-
4		Thirumalagiri	Thatipamula	11kv	Suryapet	03.30	07.20	03.50	E/L	Insulator flashover	-
5		Gaddipaly	Ponugodu	11kv	Huzurnagar	15.35	16.35	01.00	EL	Due to Tree branch fall on 11Kv line	-
6		Mothkur	Anjipur	11kv	Bhongiri	10.10	12.00	01.50	EL/OL	Bird Fallen at Line & 11kv Line Snapped near Anajipur Village	-
1	SDPT	REBARTHY	LADNUR	11kv	Husnabad	13.50	00.00	10.10	B/D	No visible fault	-
1	HYD N	Chilalguda	New Boiguda	11kv	Secunderabad	17.30	20.00	02.30	EL	AB Cable fault at Axis Bank	Partial feeder charged at 18:20 Hrs
1	HYD C	Golconda	Darga Cable	11kv	Mehdipatnam	15.10	16.45	01.35	EL,OL-Bph	3No. Cable Jumpers cut at Nagarjuna School	-----