

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Elkicherla	11KV	Jadcherla	04.20	09.25	05.05		11KV Jumper cut near Elkicherla	No
1	NLG	Solipet	Solipet	11KV	Bhongir	13:40	15:20	1:40	OL	11KV Line snapped	No
1	RR S	Nanakramguda	Church	11KV	Gachibowli	17:22	18:45	1:23		11KV AB Cable end kit failed at SC Basti	No
1	RR N	GP Pally	Dulapally	11KV	Medchal	13:45	14:35	0:50		11KV Pin Insulator failed at DRS School	No
1	HYD N	Seethaphal Mandi	Srinivasa Nagar Colony	11KV	V	06.50	08.10	01.20	EL,OL-Bph	Heavy sound on DTR at Dharani Super Market	Partial feeder charged at 07:30 Hrs
1	HYD S	Falaknuma	Farooq Nagar	11KV	III	08.55	11.49	02.54	EL	Cable fault	Partial feeder charged at 09:05Hrs & remaining loads added on 11KV Fathima Nagar feeder
2		Aliyabad	Police Quarters	11KV	III	15:39	17:02	1:23	OL	HT Lines snapped at Balaji Sweet House	No