

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	8	0	8	0	8	0	0	



TSSPDCL - LMRC / Corporate office

Date: 17.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mellavi	Pakeerpuram	11KV	Devarakonda	15.08	16.05	00.57	E/L	11Kv Jumper Cut	-
2		Kasaabada	Kesaram	11KV	Suryapet	04.20	07.15	02.55	E/L	11Kv Insulator flashover	-
3		Huurnagar-2	Singaram	11KV	Huzurnagar	08.00	11.00	03.00	E/L	11Kv jumper cut	-
4		Repala	Narsimhulagudem	11KV	Huzurnagar	11.00	12.40	01.40	E/L	Bird fall on 11kv line	-
5		Panhangi	Panhangi Agl	11KV	Chotuppal	07.40	09.05	01.25	E/L	11 kv Pin Insulator failed Near Areygudem (v)	-
1	RR S	Nanakramguda	Gowlidoddi	11KV	Gachibowli	05.56	07.02	01.06		11KV AB Cable End Kit failed near Madhava Reddy building at Gowlidoddi	-
2		Chandanagar	Rail Vihar	11KV	Gachibowli	12.10	13.15	01.05		11KV Insulator failed and 11kv Conductor Snapped near plot no 43 to 47 at Rail Vihar.	-
1	HYD S	Falaknuma	Guntal Sha Darga	11KV	Charminar	01.10	02.16	01.06	EL,OL	Cat fallen on O/G AB Switch at SS	Arranged B/F on 11KV Vattepally fdr