

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	0	6	0	6	0	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Tirumalapur	Dondlapally	11KV	Jadcherla	08.13	10.24	02.11		11Kv Jumper Cut Near Dondlapally(Vi)	-
1	NLG	Dirincherla	Somaram	11KV	Huzurnagar	04.00	06.30	02.30	EL	11 KV LINE SNAPPED	-
2		N B Gudem	Redlakunta	11KV	Huzurnagar	08.35	11.25	02.50	EL	11 KV JUMPER CUT	-
3		Athmakur	Koratikal	11KV	Bhongir	04.10	14.30	10.20	EL/OL	3 no's 11 kv Insulators Failed at Koratikal vagu Near Koratikal village.	-
1	HYD N	Road No.2	Lumbini Mall	11KV	X	19.45	21.03	01.18	EL	Cable Fault at Sagar Society	-----
2		Muffakamja College	Sulthan Uloom	11KV	X	21.59	23.04	01.05	EL,OL-Rph	Cat fallen in RMU at Sulthan Uloom College	Arranged B/F on 11KV Venkateswara Hills fdr