

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	1	0	1	0	1	0	0	
	Grand Total	1082	6468	0	5	0	5	0	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-

TSSPDCL - LMRC / Corporate office

Date: 19.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mattapally	Town	11kv	Huzurnagar	07.10	08.30	01.20	EL	11 KV LINE SNAPPED	-
1	RR S	Chanda Nagar	Tara nagar	11kv	Gachibowli	10.15	13.15	03.00	BD	Kite fallon on the 11KV line at PJR Statium	-
1	RR N	Aleap	Aleap Cable	11kv	Jeedimetla	15.15	18.00	02.45	EL/OL	11kv Endy Kit Failure In Sub Station	-
1	HYD N	New Bowenpally	Reliance Villa	11kv	Bowenpally	14.47	17.06	02.19	EL,OL	AB Cable fault at Tadbun Temple	-
1	HYD S	Petlaburz	Chowk	11kv	Charminar	13.05	14.29	01.24	EL,OL	2no Cable jumper cut at Chowk Chowrastha	-