

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	3	3	3	3	3	0	0	
	Grand Total	1082	6468	3	5	3	5	3	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G R Cable	33kv	Jadcherla	11.15	12.00	00.45	EL	Insulator failed near Khanapur village	G R Cable	-
2		Amangal	Kadthal	33kv	Shadnagar	17.15	17.40	00.25	EL	No Visbule Fault	Kadthal	-
1	NLG	Madugulapally	Thadakamalla	33kv	Miryalaguda	07.05	09.30	02.25	EL	Jumpet Cut	Thadakamalla	-

TSSPDCL - LMRC / Corporate office

Date: 20.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Anumulagudem	Singaram	11kv	Huzurnagar	06.00	07.45	01.45	EL	11 KV Inslater Failed	-
2		Alingapuram	Raghavapuram	11kv	Huzurnagar	07.00	08.30	01.30	EL	11 KV Line Snapped	-
3		Anantharam	Anantharam	11kv	Bhongiri	21.30	00.10	02.40	EL	11 KV Line Snapped Near Anantharam Village	-
1	HYD S	Panjesha	Gulzar House	11kv	Charminar	02.05	04.15	02.10	---	HT Jumper cut at Gulzar House	11KV Gulzar House fdr was under B/F on 11KV Chowk fdr
2	HYD C	Durga Nagar	Prem Nagar	11kv	Azamabad	02.43	04.10	01.27	EL,OL-Rph	Cable fault back side Dumping Yard	-----