

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	4	2	4	2	4	0	0	
	Grand Total	1082	6468	2	10	2	10	2	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Puttapad	Salkarpet	33KV	Narayanapet	12.00	15.15	03.15		LA Failure In coming AB Switch Open & CT Replaced at 33KV Salkarpet		-
2		Amangal	Mudwin	33KV	Shadnagar	20.10	00.00	03.50	EL	Y Phase line wire cut near Amangal Town		-

TSSPDCL - LMRC / Corporate office

Date: 23.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	08.07	10.08	02.01		11KV Insulator fail near Polkampally	-
2		Mallaboinpally	Mallaboinpally	11KV	Jadcherla	00.00	08.42	08.42		11KV Jumper cut near Chitta Boinpally	-
1	NLG	Palakeedu	Nagireddygudem	11KV	Huzurnagar	05.00	06.45	01.45	EL	11 KV LINE SNAPPED	-
2		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	10.43	11.43	01.00	EL	11 KV JUMPER CUT	-
1	RR N	Kompally	Jaibheri	11KV	Medchal	07.19	08.32	01.13	BD	11KV Dammy Cable touched on the 11KV Disc at Royal Park	-
2		Bowrampet	Junnurum	11KV	Jeedimetla	01.25	02.40	01.15	BD	11kv line petroling, no falt	-
1	HYD N	Bhudevi Nagar	Adarsh Nagar	11KV	Bowenpally	15.35	17.10	01.35	EL,OL	Bird fault on lines at V.M Tempe & Cable fault at SS	-
1	HYD S	Miralam	Water Works	11KV	Charminar	17.55	19.20	01.25	EL,OL-Bph	Disc Insulator flash over at Water Works	-
2		Aliyabad	Police Quarters	11KV	Charminar	23.26	00.32	01.06	EL	End Kit failed at Baber Bakery	Arranged B/F on 11KV Saradha College fdr
1	HYD C	Narayanguda	Preventive Medicine	11KV	Azamabad	20.40	21.55	01.15	EL,OL-R&Bph	Twisted lines at Narayanguda Nala (Partial fdr charged at 21:10Hrs - 60/30Amp)	-