

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	1	4	1	4	1	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD S	220KV Ch.Gutta	B.D.L	33KV	Malakpet	18.30	22.55	04.25	EL,OL-R,Y&Bph	Bph & Yph, Lightening Arrestor failed at Jumper cut at 220KV Ch.Gutta SS	B.D.L	-

## TSSPDCL - LMRC / Corporate office

Date: 25.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B.Chandupatla	Thimmapuram	11KV	Suryapet	06.15	08.45	02.30	E/L	Conductor snapped	-
2		Athmakur	Koratikal	11KV	Bhongiri	11.20	13.00	01.40	EL	11kv Insulator Failed near Koratikal Village	-
1	RR N	JTPL	Janapriya 9 Value	11KV	Kukatpally	01.38	07.00	05.22	BD	HT/LT Cable Failure at 9 Volue Apt	-
2		Laxmapur	MC Pally	11KV	Medchal	18.10	19.00	00.50	BD	Tree fallen on the 11KV Line at Forest area, Laxmapur	-