

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	3	0	3	0	3	0	0	
	Grand Total	1082	6468	0	8	0	8	0	8	0	0	



S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Akaram	Vallala	11KV	Nalgonda	13:30	14:50	1:20	EL	Insulator failed	No
1	SDPT	Gagillapur	Gagillapur Agl	11KV	Husnabad	15:15	18:25	3:10		HT / LT	No
2		Akkannapet	Gollakunta	11KV	Husnabad	04.10	08.24	04.14		HT / LT	No
1	RR S	Nanakramguda	Church	11KV	Gachibowli	1:21	2:44	1:23		11 KV AB Cable straight through Kit failed at SC Basthi near Govt School back side	No
1	RR N	Jeedimetla-III	Back Lighty Hylam	11KV	Jeedimetla	15:45	16:45	1:00		11KV Line AB cable end kit failure at Jahnavi Company Phase-IV	No
2		Suraram	Venkatram nagar	11KV	Jeedimetla	04.18	05.38	01.20		11KV Line AB cable failure at Briks Company , Sriramnagar	No
1	HYD S	Aliyabad	Sharda College	11KV	III	20.43	22.37	01.54	OL	AB Cable fault at Old ACP Office	21:35 Partial feeder charged
1	HYD C	Narayanguda	City Central Library	11KV	I	14.30	15.45	01.15	EL,OL	Opened Auto relcosers at TVS Motors	No