

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.01.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Utkoor	33KV	Narayanpet	10.40	15.30	04.50	EL	1 Pole damaged and Pole erection work at Sangamanda village	Utkoor	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Akaram	Akaram	11KV	Nalgonda	4:10	7:50	3:40	E/L	11KV Jumper cut	No
2		Chandampeta	Chitryala	11KV	Devarakonda	09.10	11.20	02.10	E/L	11KV Line Cut	No
3		Angadipeta	P.A.Pally rural	11KV	Devarakonda	06.55	11.48	04.53	E/L	11KV Conductor snpped	No
4		Damercherla	T V Gudem	11KV	Miryalguda	08.40	13.25	04.45	E/L	11KV Conductor snpped at Veerakoti Reddy agl land	No
5		Durajpally	Durajpally	11KV	Suryapet	03.45	06.15	02.30	E/L	Tree branch fallen on the11KV line	No
6		Dirsincherla	Chillepally	11KV	Huzurnagar	18:15	19:20	1:05	E/L	11KV Jumper cut	No
1	SDPT	Gagillapur	Vallampatla	11KV	Husnabad	14:10	18:00	3:50		Insulator failed	No
1	RR E	Nacharam indore	Ram reddy nagar	11KV	Habsiguda	13:18	14:31	1:13		Vechaical dashed 11KV pole at ESI Hospital	No