

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 31.01.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kethepally	Inupamula	11KV	Nalgonda	14.10	16.30	02.20	E/L	11KV Jumper cut	-
2		Angadipeta	P.A.Pally rural	11KV	Devarakonda	06.00	07.50	01.50	E/L	11 KV Jumper Cutt	-
3		Palakaveedu	Sajjapuram	11KV	Huzurnagar	10.30	13.30	03.00	E/L	Due to 11Kv Disk Failure	-
4		Mattampally	Choutapally	11KV	Huzurnagar	19.49	21.40	01.51	E/L	Due to 11Kv line snapped	-
5		Mellacheruvu	Revooru	11KV	Huzurnagar	02.50	05.40	02.50	E/L	Due to 11Kv Disk Failure	-
1	MDK	EPIP-II	Export	11KV	Sangareddy	11.48	12.48	01.00		BD DUE TO INSULATOR FAIL	-
2		Bollaram - I	Town -I	11KV	Patancheru	08.25	09.00	00.35		BD DUE TO JUMPER CUT	-
1	RR S	Nanakramguda	Church	11KV	Gachibowli	03.04	04.28	01.24		Tipper vehicle dashed to 11kv Line , 11kv Line cut at baloon company, Nanakramguda	-
1	HYD N	N.I.M.S	Chief Justice	11KV	Banjarahills	00.05	01.18	01.13	EL	Cable fault	Arranged B/F on 11KV Banjara Hills fdr
1	HYD S	Santosh Nagar	Bhavani Nagar	11KV	Asmangadh	23.35	00.58	01.23	EL,OL-Bph	Breaker problem at SS	Arranged B/F on 11KV Moula Ka Chilla fdr
1	HYD C	Vittalwadi	APCO	11KV	Azamabad	11.25	12.35	01.10	EL,OL-Rph	Faulty DTR at Srinivasa Residency	-