

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		12		12		12			
	Total	606	3055	0	15	0	15	0	15	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		3		3		3			
3	MDK	107	933	3		3		3				
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	7	4	7	4	7	0	0	
	Grand Total	1082	6468	4	22	4	22	4	22	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.07.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	Gattu	33KV	Gadwal	14.38	14.55	00.17	E/L	Due to Breaker Problem	Gattu	Alternate Supply Arranged from 33KV Mitta Doddy at 14:55Hrs.
1	MDK	R.C.Puram	NSL	33KV	Patancheru	20:20	23:45	3:25		Tree branches fallen on the line	NSL	No
2		R.C.Puram	Ambuja	33KV	Patancheru	20.25	23.25	03.00		Jumper cut	Ambuja	No
3		Kandi	Alkabeer	33KV	Sangareddy	19.50	23.50	04.00		Jumper cut	Alkabeer	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Thirmalagiri	11KV	Jadcherla	11.00	13.58	02.58		11 KV Insulator failed near Aasramam.	No
1	NLG	Ch.Annaram	Vallala	11KV	Nalgonda	9:00	10:30	1:30	EL	Insulator failed	No
2		Jalalpuram	Velishala	11KV	Suryapet	12.15	14.50	02.35	EL	Disc failed	No
3		Munagala	Barakathgudem	11KV	Huzurnagar	15.30	16.30	01.00	EL	11 KV Line snapped	No
1	SDPT	Ponnal	Ponnal	11KV	Siddipet	3:30	11:00	7:30		Insulator failed	No
2		Markook	Sneha Industrial	11KV	Gajwel	14:34	15:38	01.04		LT Line melt	No
3		Ganeshpally	Angadi Kistapur	11KV	Gajwel	12.50	14.20	01.30		LT Line melt	No
1	RR N	Hudatruck park	Shivalayam	11KV	Kukatpally	0:30	1:50	1:20	EL	11KV Pin insulator failure at Kukatpally main road	No
1	RR E	NGRI	HMT Nagar	11KV	Habsiguda	4:09	5:04	0:55		Coconut tree fallen on 11KV line & Line snapped at St.No.11 HMT Nagar	No
2		Cherlapally I	EC Computers	11KV	Sainikpuri	21.15	22.10	00.55		11KV Pin insulator failed near KLR Company	No
1	HYD N	Zamistanpur	Sanjeevapuram	11KV	V	00.08	02.30	02.22	EL,OL-Rph	Insulator flash over at Sanjeevapuram	Arranged B/F on 11KV Srinivas Nagar Colony feeder
2		Prashanth Nagar	Sony Complex	11KV	VI	1:15	2:19	1:04	EL,OL-Bph	Disc Insulator flash over at IDPL Pump House	No
3		Chilkaiguda	Water Works	11KV	V	6:05	7:45	1:40	EL	RMU fault at Water Works	Arranged B/F on 11KV P.R.Nagar fdr
4		Ravindra Society	Ginger Court	11KV	X	21:20	22:30	1:10	EL,OL	No Visible Fault	Arranged B/F on 11KV C.O.D. fdr
1	HYD S	Ch' Baradari	SRT Colony	11KV	III	00.25	02.15	01.50	EL,OL	Tree branches fallen on lines at Baradari Ch'	No
1	HYD C	Z.P Office	Anand Nagar	11KV	I	01.04	02.16	01.12	EL,OL-Rph	AB Switch male female contact flash over at Anand Nagar	No
2		Erramanzil	I.C Quarters	11KV	I	01.10	02.50	01.40	EL	Insulator flash over at Jala Soudha	No
3		Golconda	Shaikpet Water Works	11KV	VII	12.05	13.15	01.10	EL	Disc Insulator flash over at Gulshan Colony	No
4		ITI Mallepally	Afzal Sagar	11KV	VII	14.48	17.59	03.11	EL,OL	I/C Cable fault at ITI Mallepally	Arranged B/F at 15:57Hrs on 11KV Nampally Hospital fdr but not hold, Arranged B/F on 11KV Anwar Ulloom feeder
5		Nampally	Nampally Hospital	11KV	VII	15.58	17.28	01.30	OL	Faulty loads of 11KV Afzal Sagar feeder	No
6		Golconda	Q.Q.Toombs	11KV	VII	21:30	0:20	2:50	EL	Big tree fallen on lines & lines twisted at Noor Masjid	Arranged B/F on 11KV Golconda OH feeder
7		A.S.R.Raju Nagar	Ushodaya Colony	11KV	VII	23.56	01.10	01.14	EL	Tree branches fallen on lines at Navodaya Colony	No