

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	5	2	5	2	5			
2	NLG	144	988		12		12		12			
3	MDK	107	933		1		1		1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	21	2	21	2	21	0	0	
	Grand Total	1082	6468	2	21	2	21	2	21	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Chinnamaroor	33KV	Wanaparthi	03.30	06.50	03.20	O/L	Pin Insulator Damaged at Srinivasapur		-
2		Ghanapur	Lattupally	33KV	Wanaparthi	03.42	09.11	05.29	O/L	Tree Fallen on the Line Near Gorita(V)		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 03.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Kanmankalwa	11KV	Jadcherla	00.00	07.08	07.08		11KV Jumper cut near Kothapally	-
2		Moosapet(Vemula)	Dasaripally	11KV	Jadcherla	05.28	12.58	07.30		11KV Disc Failed near Dasaripally	-
3		Kandoor	Choudaipally	11KV	Jadcherla	07.50	09.00	01.10		11KV Insulator Failed near Choudaipally	-
4		Ponnakal	Rachala	11KV	Jadcherla	01.00	08.00	07.00		11KV Jumper cut Near Dubbapally	-
5		Boothpur	Amistapur Agl	11KV	Jadcherla	00.00	07.45	07.45		11KV Wire cut Near Amistapur	-
1	NLG	Cherkupally	Cherkupally	11KV	Nalgonda	10.00	12.15	02.15	E/L	11KV jumper cut	-
2		Nakrekal	Nomula	11KV	Nalgonda	10.23	11.50	01.27	E/L	11KV jumper cut	-
3		Eduloor	Kurumarthy	11KV	Nalgonda	03.30	09.00	05.30	E/L	11KV jumper cut	-
4		Rajupeta	Bandavarigudem	11KV	Nalgonda	08.50	10.05	01.15	E/L	Tree branch fallen on line	-
5		Indugula	Kothagudem	11KV	Nalgonda	01.15	06.55	05.40	E/L	11KV jumper cut	-
6		Mushampally	Muthyalamma	11KV	Nalgonda	00.15	11.30	11.15	O/L	Jumper cut at SS-1	-
7		Cherkupally	Bondagu	11KV	Nalgonda	14.10	15.25	01.15	E/L	11KV insulator failed	-
8		Yerkaram	Rajunaik Thanda	11KV	Suryapet	07.40	10.00	02.20	E/L	Insulator failed	-
9		Gaddipally	Kutubshapuram	11KV	Huzurnagar	05.00	07.30	02.30	E/L	11kv Line Snapped	-
10		Thogarrai	Ganapavaram	11KV	Huzurnagar	11.50	12.50	01.00	E/L	11kv Line Snapped	-
11		Maryala	Chowderpally	11KV	Bhongir	10.30	13.10	02.40	EL/OL	11kv Line Snapped near Chppari thanda	-
12		Rajapeta	Renikunta Agl	11KV	Bhongir	00.18	07.15	06.57	EL/OL	11 kv insulator failed near Renikunta village.	-
1	MDK	Sangareddy Rural	Balaji	11KV	Sangareddy	04.30	11.20	06.50		B/D due to Disk failed	-
2	SDPT	JAGADEVPUR	DOWLAPUR AGL	11KV	Gajwel	08.35	00.30	11.28		DISC FAIL	-
3		BANDARAM	BANDARAM	11KV	Gajwel	11.35	08.40	13.20		11KV POLE DAMAGED	-
4		Narayanaraopet	Rajannagudi	11KV	Siddipet	03.00	08.10	01.52		B/D - Tree branches fallen on the line	-