

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	6	1	6	1	6			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044									
	Total	606	3055	1	9	1	9	1	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988	2	11	2	11	2	11			
3	MDK	107	933									
4	SDPT			3	25	3	25	3	25			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	39	6	39	6	39	0	0	
	Grand Total	1082	6468	7	48	7	48	7	48	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Jadcherla	33KV	Mahabubnagar	18.40	18.50	00.10	O/L	Cable Kit Damaged Near Railway track Badeypally signal gadda		-
1	NLG	Nalgonda	Rayanguda	33KV	Nalgonda	15.55	17.30	01.35	EL	Jumper cut		-
2		Suryapet	HPCL	33KV	Suryapet	10.30	13.25	02.55	EL	Conductor snapped & Pin insulator failed		-
1	SDPT	Habsipur	Raghothampally	33KV	SDPT	01.10	06.58	05.48		BD (Havey Rain Tree Cutting)		-
2		Doultabad	Mubaraspur	33KV	GAJWEL	05.28	06.28	01.00		BD (Insulator failed)		-
3		Angadi kistapur	Jagadevpur	33KV	GAJWEL	01.20	06.23	05.03		BD (Insulator failed)		-
1	RR N	132KV Medchal	33KV Devaramjal	33KV	Medchal	04.00	12.10	08.10		Tree fallen on the 33KV Line at near Devarayamjal SS		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 04.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Tirumalagiri	11KV	Jadcherla	07.30	09.30	02.00		Bird Died On The 11KV Line near Tirumalagiri(V)	-
2		Marikal	Kanmankalva	11KV	Jadcherla	08.30	10.45	02.15		11KV Jumper Cut Near Kothapally (V)	-
3		Teegalapally	Kakarllaphad	11KV	Jadcherla	22.00	08.00	10.00		11KV Jumper Cut Near Kakarllaphad (V)	-
1	NLG	Palem	Bopparam	11KV	Nalgonda	03.30	10.25	06.55	E/L	11 KV Jumper Cut	-
2		Chervugattu	Sheribaigudem	11KV	Nalgonda	03.55	07.40	03.45	E/L	11 KV Jumper Cut	-
3		Eduloor	Naregudem	11KV	Nalgonda	00.30	06.00	05.30	E/L	11 KV Tree Branch Fallen on 11 KV Line	-
4		Eduloor	Munukuntla	11KV	Nalgonda	02.30	06.15	03.45	E/L	Control AB Switch Burned	-
5		Narketpally	M.Yedavally	11KV	Nalgonda	02.20	08.10	05.50	E/L	11 KV Jumper Cut	-
6		Ch.Annaram	Ch.Annaram	11KV	Nalgonda	03.20	06.55	03.35	O/L	11 KV Tree Branch Fallen on 11 KV Line	-
7		Kethepally	Korlapahad	11KV	Nalgonda	06.00	07.30	01.30	E/L	Thati Matta Fallen on DTR under SS-8	-
8		Chedella	Chedella	11KV	Suryapet	13.00	16.40	03.40	E/L	Insulator failed	-
9		Ananthagiri	Ameenabad	11KV	Huzurnagar	05.30	07.15	01.45	EL	11 KV LINE SNAPPED	-
10		Timmareddygudem	Ganapavaram	11KV	Huzurnagar	04.30	07.00	02.30	EL	11 KV INSLATER FAILED	-
11		Vemulakonda	Goparajupally	11KV	Choutuppal	07.00	10.00	03.00	EL/OL	11 kv Disc failed at Bhadrabiona sudarshan well near Goparajupally village	-
1	SDPT	Husnabad	Pandilla	11KV	SDPT	13.45	15.15	01.30		INSULATOR FAILURE	-
2		GOURAVELLY	GUDATIPALLY	11KV	SDPT	00.00	08.00	08.00		JUMPER CUT	-
3		GANDIPALLY	RAMAVARAM	11KV	SDPT	00.00	06.10	06.10		INSULATOR FAILURE	-
4		samudrala	laxmipur	11KV	SDPT	05.00	09.30	04.30		conductor snapped	-
5		koheda	canal	11KV	SDPT	07.45	08.35	00.50		INSULATOR FAILURE	-
6		gurjakunta	domata	11KV	SDPT	00.00	11.00	11.00		conductor snapped	-
7		Guruvannapet	Guruvannapet	11KV	SDPT	00.00	06.35	06.35		INSULATOR FAILURE	-
8		Guruvannapet	posanpally	11KV	SDPT	00.00	06.35	06.35		due to rain	-
9		Guruvannapet	tapaspally	11KV	SDPT	06.35	13.25	06.50		conductor snapped	-
10		chityal	chityal 7hrs	11KV	SDPT	01.05	12.15	11.10		INSULATOR FAILURE	-
11		KOMURAVELLY	KADAVRUGU	11KV	SDPT	00.30	05.40	05.10		INSULATOR FAILURE	-
12		GAJWEL	TOWN-II LC.NO:5804	11KV	GAJWEL	22.00	00.45	02.45		TREE BRANCH FALL OVER 11KV	-
13		GAJWEL	TOWN-II LC.NO:5804	11KV	GAJWEL	16.00	16.20	00.20		CABLE CUT	-
14		GURRALASOPA	RAMARAM LC.NO:4225	11KV	GAJWEL	06.50	08.05	01.15		INSULATOR FAIL	-
15		JAGADEVPUR	DOWLAPUR AGL LC.NO:5568	11KV	GAJWEL	15.30	17.55	02.25		DISC FAIL	-
16		NEMTUR	NEMTUR LC.NO:40251	11KV	GAJWEL	05:40	08:40	03.00		TREE BRANCH FALL OVER 11KV	-
17		KOKKONDA	KOTTHUR LC.NO:37077	11KV	GAJWEL	00.00	06.50	06.50		INSULATOR FAIL	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
18		MULUGU	MULUGU TOWN LC.NO:14469	11KV	GAJWEL	02.15	06.20	04.05		INSULATOR FAIL	
19	SDPT	DOMMATA	GAJULAPALLY LC.NO:326	11KV	GAJWEL	06:45	09:06	02.21		TREE BRANCH FALL OVER 11KV	
20		DUDEDEA	SELAMPUR LC.NO:21268	11KV	GAJWEL	12.50	14.20	01.30		TREE BRANCH FALL OVER 11KV	
21		DUDEDEA	DUDEDEA AGL LC.NO:21267	11KV	GAJWEL	09.00	10.50	01.50		TREE BRANCH FALL OVER 11KV	
22		MARPADAGA	MARPADAGA AGL-II LC.NO:28191	11KV	GAJWEL	23.40	07.50	08.10		DISC FAIL	
23		KARKAPATLA	KARKAPATLA AGL LC.NO:30670	11KV	GAJWEL	14:40	17:30	02.50		HT/LT	
24		ERRAVALY	NARSANNAPETA LC.NO26311	11KV	GAJWEL	17:11	09:11	02.00		INSULATOR FAIL	
25		ERRAVALY	NARSANNAPETA LC.NO26321	11KV	GAJWEL	16:05	16:40	00.35		DISC FAIL	
1		RR N	Dulapally	Steel City	11KV	Medchal	01.45	02.50	01.05		No fault(Due to Rain)
2	Subhash Nagar		Suchitra	11KV	Medchal	02.50	04.50	02.00		11KV Line AB Switch Opened at Karachi Bekary(Disc failed at Perical Electrical Shop)	-
3	Chintal		Surya Nagar	11KV	Medchal	01.55	02.35	00.40		11KV Line AB Switch Opened at 1st Line AB Switch, Surya Nagar(11KV Pin Insulator failed)	-
4	Nuthankal		Nuthankal	11KV	Medchal	01.45	02.50	01.05		11KV Line Cut & replaced at Yellamma Temple	-
5	Thurkapally		Thurkapally	11KV	Medchal	05.30	07.20	01.50		11KV Pin Insulator failed at Old Gram Panchayat Backside, Thurkapally(AB Switch Closed at Dharma Reddy Thota)	-
6	Devarayamjal		Kottapet	11KV	Medchal	00.02	01.40	01.38		11KV Pole damaged By Lorry at Agarkhan Hostel(11KV Line AB Switch Opened)	-
1	RR E	VP Nagar	VV Puram	11KV	Sainikpuri	04.22	05.18	00.56		11Kv Pin Insulator failed at Raghavendra Nagar (LM Chandra Shekar)	-
2		AS Rao Nagar	AS Rao Nagar	11KV	Sainikpuri	00.08	01.34	01.26		11Kv line cut at Vijaya Daiygnastic Back side (Artisan/Ravinder)	-
3		Janapriya	Greenpark	11KV	Sainikpuri	03.00	04.00	01.00		11Kv Pin Insuletor fail at Shivapuri Enclave (AE)	-