

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	2	3	2	3	2			
2	NLG	144	988		13		13		13			
3	MDK	107	933		2		2		2			
4	SDPT			1	17	1	17	1	17			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	34	4	34	4	34	0	0	
	Grand Total	1082	6468	4	39	4	39	4	39	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.07.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33KV	Mahabubnagar	12.30	13.00	00.30	E/L & O/L	33KV Conductor snapped	Hanwada	Alternate Supply Arranged to 132KV SS Maddur at 13:00Hrs
2		Wanaparthi	Chinnamaroor	33KV	Wanaparthi	14.55	16.15	01.20	O/L	Due to PTR-II LV's Pulled out	Chinnamaroor	No
3		Amarchintha	Atmakur	33KV	Wanaparthi	19.50	20.00	00.10	E/L	Insulator damaged near Athmakur	Atmakur	Alternate supply arranged from 33KV Amarchintha
1	SDPT	Palamakula	Gonepally	33KV	Siddipet	20:20	23:45	3:25		Due to heavy rain	Gonepally	Alternate Supply arranged from 11KV Side

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Kothamolgara	11KV	Jadcherla	10.10	11.45	01.35		11 KV Jumper cut near kappeta (V)	No
2		Midjil	Veljal	11KV	Jadcherla	04.25	13.00	08.35		11 KV Insulater and DTR insulater failed near Pedda Gundla Thanda.	No
1	NLG	Thurkapally	M.Gouraram	11KV	Nalgonda	5:00	6:30	1:30	E/L	Insulor failed	No
2		S.Goraram	S.Gouraram	11KV	Nalgonda	07.30	08.39	01.09	E/L	11 KV Jumper cut	No
3		Rayanigudem	Koriveni Gudem	11KV	Nalgonda	11.20	13.10	01.50	E/L	11 KV Tree branches fallen on the 11 KV line	No
4		Pajjur	P.Suraram	11KV	Nalgonda	07.30	09.10	01.40	E/L	Disc failed	No
5		KOTHAGUDEM	GUDUR	11KV	Miryalaguda	06.25	09.00	02.35	E/L	100KVA DTR failed near Gudur villages	No
6		KANNEKAL	MACHANAPALLY	11KV	Miryalaguda	07.59	10.00	02.01	E/L	11 KV Pin insulator failed at Machanapally village	No
7		AGAMOTHKUR	CHIRUMARTHY	11KV	Miryalaguda	06.25	09.00	02.35	E/L	11 KV Pin insulator failed at Madhusudan Reddy Agl DTR Chirumarthy village	No
8		KAMAREDDY GUEDEM	KAMAREDDY GUEDEM	11KV	Miryalaguda	06.35	09.30	02.55	E/L	11KV Jumper cut near Kamareddy gudem villages	No
9		G.T Giri	Gunjaloor	11KV	Suryapet	03.50	08.20	04.30	E/L	Disc flashover	No
10		Kasarabada	Express	11KV	Suryapet	03.40	08.00	04.20	E/L	Insulator flashover	No
11		Thungathurthy	Banda Ramaram	11KV	Suryapet	12.30	14.00	01.30	E/L	Jumper cut	No
12		Venkatapur	Dathaipally	11KV	Bhongir	06.00	13.50	07.50	E/L	11 KV Disc failed	No
13		Chamapur	Chamapur	11KV	Bhongir	9:26	11:00	1:34	E/L	11 KV Insulator failed	No
1	MDK	Kistareddypet	Patelguda	11KV	Patancheru	10:15	11:45	1:30		Jumper cut	No
2		Hathnoora	Town	11KV	Jogipet	18.20	19.00	00.40		Tree branch fallen on the line	No
1	SDPT	Mustabad X-Road	Gadicherlapally	11KV	Siddipet	1:12	7:05	5:53		Due to heavy rain	No
2		Gurralagondi	Malyala	11KV	Siddipet	20.00	23.45	03.45		Due to heavy rain	No
3		Jakkapur	Jakkapur	11KV	Siddipet	20.20	01.13	04.53		Due to heavy rain	No
4		Jakkapur	Shanigakunta	11KV	Siddipet	07.10	10.26	03.16		Tree fallen on the line	No
5		Mittapally	Yellupally	11KV	Siddipet	20.25	23.45	03.20		Due to heavy rain	No
6		Chittapur	Chowdarpally	11KV	Siddipet	09.30	10.23	00.53		Tree fallen on the line	No
7		Dharmajipet	Rengondaswamy	11KV	Siddipet	19.00	23.45	04.45		Due to heavy rain	No
8		Habsipur	Dharmaram	11KV	Siddipet	13.00	21.00	08.00		Due to heavy rain	No
9		Chatlapally SS	Anthyaguda	11KV	Gajwel	02.55	10.54	07.59		Disk fail	No
10		Jagdevpur SS	Jagdevpur Town	11KV	Gajwel	19.05	20.05	01.00		Jumper cut	No
11		POTHARAM	POTHARAM TOWN	11KV	Husnabad	09.00	09.50	00.50		Line snapped	No
12		AKKANAPET	PAKILNAYAK THANDA	11KV	Husnabad	15.15	17.15	02.00		1-PH OK 3-PH BD	No
13		DHARMARAM	Dharmaram(R.)	11KV	Husnabad	18.46	19.15	00.29		Due to heavy rain	No
14		DHARMARAM	Nandaram	11KV	Husnabad	18.40	21.40	00.00		Line snapped	No
15		PANDILLA	pandilla rural	11KV	Husnabad	20.30	21.20	00.50		Due to heavy rain	No
16		BEJJANKI	KALLLEPALLY	11KV	Husnabad	19.30	21.30	02.00		1-PH OK 3-PH BD	No
17		BEJJANKI	MUTHANNAPET	11KV	Husnabad	20:30	22:30	2:00		1-PH OK 3-PH BD	No
1	RR N	Jeedimetla-IV	Auto Stand	11KV	Jeedimetla	1:06	2:10	1:04	EL	CT PT Failure & 11KV Jumper cut	No
2		Nuthankal	Grip	11KV	Medchal	04.45	05.35	00.50	EL	11KV Pin Insulator Failed and replaced at Yellamma Temple backside, Nuthankal	No
3		Devarayamjal	Pothaipally	11KV	Medchal	15.20	16.45	01.25	EL/OL	11KV Jumper cut at Pothaipally Village	No
4		Town Medchal	NGO's Colony	11KV	Medchal	16.25	17.15	00.50	EL/OL	11KV Jumper cut at Medchal main road	No
1	RR E	Ghatkesar	Balaji Nagar	11KV	Keesara	13:00	14:30	1:30		11KV Pin insulator failed at Kondapur Village	No