

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	10	2	10	2	10	0	0	
	Grand Total	1082	6468	2	14	2	14	2	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Chinnamaroor	33kv	Wanaparthi	14.22	15.30	01.08	EL&OL	Conductor Snapped	Chinnamaroor	-
2		Gadwal	Maldakal	33kv	Gadwal	15.40	17.42	02.02	EL	Flash Over Disc Failed near New Police station Maldakal	Maldakal	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 07.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nakrekal	Chandampally	11kv	Nalgonda	07.35	11.00	03.25	E/L	11KV Disc failed	-
2		Penpahad	Potlapahad	11kv	Suryapet	07.15	09.00	01.45	E/L	Jumper cut	-
3		Jai kesaram	Assonigudem	11kv	Choutuppal	00.10	07.40	07.30	EL/OL	63 kva DTR Failed & 11 kv Insulator failed & 11 KV Post off insulator failed near Cheepiri gutta village	-
1	SDPT	Komuravelli	Komuravelli AGL	11kv	Husnabad	14.10	15.40	01.30		Cable burnt	-
2		Ramchandrapur	Varikolu	11kv	Husnabad	00.30	07.00	06.30		Break down	-
3		Akberpet	Akberpet	11kv	Siddipet	06.50	08.20	01.30		B/D-Insulater Fail	-
4		Kookonda SS (9492080795)	Baswapur Industrial Feeder LC.No.37088 (Balaiah LM)	11kv	Gajwel	21.45	23.55	02.10		LT/HT fallen	-
5		Markook SS	Markook AGL Feeder LC.No.11723 (Bhaskar CL)	11kv	Gajwel	12:00	18:23	06.23		11KV Line cut	-
6		Pamulaparthi SS	Indra Nagar Feeder LC.No.25331 (Chandram CL)	11kv	Gajwel	12:00	12:40	00.40		LT/HT fallen	-
7		Ganesh Pally SS	Angadikistapur Feeder LC.No.32336 (Suresh CL)	11kv	Gajwel	15:05	17:25	02.20		LT/HT fallen	-
1	RR N	Laxmapur	Laxmapur	11kv	Medchal	15:05	17:25	02.20		Bird fallen on the 11KV Line at Laxmapur Thanda	-
1	RR E	IDA Uppal	Srikrishna	11kv	Habsiguda	12.25	13.15	00.50		33KV Tower Stay wire touched to 11KV Line near Volkvogon Company	-
2		Cherlapally	Rampally	11kv	Keesara	19.05	20.15	01.10		Bird fallen on 11KV line near J K Powder Company	-
1	HYD C	Asif Nagar	N.S.F Colony	11kv	VII	11.45	13.02	01.17	OL	No Visible Fault	Arranged B/F on 11KV Kakatiya Nagar feeder