

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	15	1	15	1	15	0	0	
	Grand Total	1082	6468	1	19	1	19	1	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.07.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Amrabad	33KV	Nagarkurnool	08.50	13.25	04.35	E/L	33KV Jumper cut near Rangapur (V)	Amrabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udityal	Macharam	11KV	Jadcherla	08.17	09.10	00.53		11 KV Disc failed near Jalgadda Thanda	No
2		Kothamolgara	Karvena	11KV	Jadcherla	12.26	14.22	01.56		11 KV Wire cut near Karvena (V)	No
3		Balanagar	Gouthapur	11KV	Jadcherla	00.00	09.00	09.00		11 KV Wire cut and Insulater failed near Gouthapur (V)	No
1	NLG	Eduloor	Akaram	11KV	Nalgonda	14:20	15:45	1:25	EL	11KV Jumper cut	No
2		Seethya Thanda	Seethya Thanda	11KV	Miryalaguda	15.25	18.00	02.35	EL	11 KV Tree branches fallen on the line	No
3		Chedella	Chedella	11KV	Suryapet	14.55	16.50	01.55	E/L	Insulator flashover	No
4		Athmakur(s)	T Penpahad	11KV	Suryapet	13.40	16.20	02.40	E/L	Jumper cut	No
5		Gondiyala	Gondiyala-2	11KV	Huzurnagar	05.00	07.15	02.15	EL	11 KV Line snapped	No
6		Ponugodu	Kothagudem	11KV	Huzurnagar	12.15	13.15	01.00	EL	11 KV Line snapped	No
7		Anantharam	Hanmapur	11KV	Bhongir	00.00	06.20	06.20	EL/OL	11 KV Insulator failed near Hanmapur village	No
8		Nemaragommula	Jameelapet	11KV	Bhongir	1:10	8:20	7:10	EL/OL	11 KV Insulator failed at Water Tank near Rayaraopet village.	No
1	SDPT	Cherial Town	Rollabanda Agl	11KV	Husnabad	12:12	14:50	2:38		Bird fallen on the line	No
2		Chellapur	Rajakkapet	11KV	Siddipet	17:28	18:37	1:09		Tree branches fallen on the line	No
3		Peddacheekode	Kammarpally	11KV	Siddipet	15:30	16:00	0:30		No visible fault still single phase arranged	No
4		Dharmajipet	Yegondaswamy	11KV	Siddipet	0:00	6:00	6:00		Tree branches fallen on the line	No
1	RR E	Cherlapally-I	EC Computer	11KV	Sainikpuri	23:15	0:05	0:50		Lorry Dashed to 11KV pole near Cherlapally Jail	No
1	HYD S	Kandikalgate	Rakshapuram	11KV	III	06.58	08.10	01.12	EL,OL-Bph	HT Jumper cut & 2No. Pin Insulators flash over at Tea Stall	No
1	HYD C	Lake View	Vijaya Hospital	11KV	I	03.28	05.30	02.02	EL,OL-Bph	Cable fault at Vijaya Hospital (2No. DTR's Kept Off)	No
2		Industrial Area	R.O.M	11KV	II	16.30	17.45	01.15	EL	Tree branches fallen on lines at RTC Kalyana Madapam & O/G jumper cut at SS	No