

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		9		9		9			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	10	0	10	0	10	0	0	
	Grand Total	1082	6468	0	17	0	17	0	17	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD N				NIL							-
9	HYD S				NIL							-
10	HYD C				NIL							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 13.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kodur	Loyapally	11KV	Suryapet	10.25	12.30	02.05	E/L	Conductor snapped	-
2		Dhupahad	New Banjarahills thanda	11KV	Suryapet	04.25	07.55	03.30	E/L	Insulator failed	-
3		Akupamula	Singaram	11KV	Huzurnagar	12.50	14.30	01.40	EL	11 KV LINE SNAPPED	-
4		Nakrekal	Nomula	11KV	Nalgonda	11.55	12.50	00.55	EL	11 KV Line Jumper Cut	-
5		Yacharam	Annaram	11KV	Miryalaguda	11.02	11.45	00.43	EL	Jumper Cut at Annaram Village	-
6		Haliya	Naidupalem	11KV	Miryalaguda	05.30	07.40	02.10	EL	Insulator failed at Naidupalem Village	-
7		Velmagudem	Velmagudem	11KV	Miryalaguda	14.40	15.20	00.40	EL	Jumper Cut at Velmagudem Raod	-
8		NG.Bandal	Veerareddy pally	11KV	Bhongir	11.00	16.30	05.30	EL/OL	11kv Insulator Failed near SS-5 Village	-
9		Athmakur	Koratikal	11KV	Bhongir	09.00	11.00	02.00	EL/OL	11kv Insulator Failed near Koratikal Village	-
1	SDPT	Regulapally	Regulapally	11KV	Husnabad	06.00	12.00	06.00		BD DUE TO 11KV LINE WIRE CUT	-
1	RR N	Pudur	Ramalayam	11KV	Medchal	04.45	06.25	01.40		11KV Pole damaged By Lorry at ORR, Muneerabad	-
1	RR E	Polytechnic	Srinivasapuram	11KV	Habsiguda	16.58	17.50	00.52		Tree branches fallen on 11KV line at Srinivasapuram St.No.02 due to Rain & gale	-
1	HYD C	Durga Nagar	Prem Nagar	11KV	II	01.24	04.20	02.56	EL,OL-Rph	I/C Cable fault at SS	Arranged B/F on 11KV Patel Nagar feeder
2		Industrial Area	Barkathpura	11KV	II	16.10	17.20	01.10	EL,OL	No Visible Fault	17:10Hrs & remaining loads added on 11KV Sri
3		Fever Hospital	Tourist Hotel	11KV	II	16.20	18.30	02.10	EL	Tree branches fallen on lines at Tourist Hotel	-----
1	HYD N	Zamistanpur	S.P College	11KV	V	20.55	22.08	01.13	All Indication	AB Cable fault at Heritage Fresh	-----
2	HYD S	Attapur	N.M.Guda OH	11KV	III	16.10	17.33	01.23	EL	Pin Insulator flash over at Mallaiah Tower	-----