

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		10		10		10			
	Total	606	3055	1	15	1	15	1	15	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	7	2	7	2	7			
2	NLG	144	988		12		12		12			
3	MDK	107	933		2		2		2			
4	SDPT				12		12		12			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	33	2	33	2	33	0	0	
	Grand Total	1082	6468	3	48	3	48	3	48	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Chinchode	33KV	Jadcherla	06.35	08.15	01.40	E/L	Line Isloter open at Burgulla	Chinchode	-
2		Makthal	Kirshna	33KV	Narayanapet	00.15	00.55	00.40	E/L	Insulator Failed	Kirshna	Alternate Supply Arranged from 33KV Gudeballore at 0:55Hrs
1	RR N	Medchal	Petbasheerabad	33KV	Medchal	17.05	19.36	02.31	EL	No Fault (Back Feeding arranged from 33KV Subhash nagar feeder from 17:13)	Petbasheerabad	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Serivenkatapur	Serivenkatapur	11KV	Mahabubnagar	12.00	13.22	01.22		11KV HT/LT Serivenkatapur	-
2		Gundumal	Gundumal Agl	11KV	Narayanapet	00.30	08.50	08.20		Break Down Disk Problem	-
3		Karkonda	Karkonda	11KV	Jadcherla	03.50	07.20	03.30	OL	11 KV wire cut near Raam prasad thota.	-
4		Karvena	Karvena	11KV	Jadcherla	11.18	14.38	03.20	EL	11 KV insulater fail near Prasad company.	-
5		Nawabpet	Kondapur	11KV	Jadcherla	04.00	10.00	06.00	EL	11 KV Disk fail near Kondapur (v)	-
6		Nawabpet	Lokirev	11KV	Jadcherla	05.00	07.00	02.00	EL	11 KV insulater fail near at Nawabpet	-
7		Gangapur	Alwanpally	11KV	Jadcherla	08.00	13.30	05.30	EL	11KV disk fail near Signal gadda	-
1	NLG	Eduloor	Munukuntla	11KV	Nalgonda	08.30	13.50	05.20	EL	HT/LT melting	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	01.26	10.00	08.34	EL	11KV Insulator failed	-
3		Thummadam	Thummadam	11KV	Miryalaguda	03.00	06.10	03.10	EL	Insulator failed	-
4		Damarchrla	Damarcherla	11KV	Miryalaguda	03.00	06.00	03.00	EL	Coductor Snaped	-
5		Gundepuri	Pasthala	11KV	Suryapet	02.40	07.10	04.30	EL	Insulator flashover	-
6		Bopparam	Kothagudem	11KV	Suryapet	03.30	07.40	04.10	EL	Insulator flashover	-
7		Shantinagar	Bojjagudem	11KV	Huzurnagar	08.00	10.30	02.30	EL	11 KV LINE SNAPPED	-
8		Kondamadugu	Kondamadugu Agl	11KV	Bhongir	09.10	14.10	05.00	EL	11 KV Insulator failed	-
9		Kapraipally	Kapraipally	11KV	Bhongir	03.00	09.45	06.45	EL	11 kv Insulator failed	-
10		Malkapur	Malkapur Agl	11KV	Choutuppal	05.00	11.00	06.00	EL	11 kv Line snapped	-
11		Mandollagudem	Mandollagudem	11KV	Choutuppal	02.00	08.15	06.15	EL	11 kv Line snapped	-
12		Varkatpally	Gokaram	11KV	Choutuppal	00.00	07.50	07.50	EL	11 kv Post off Insulator failed	-
1	MDK	Bonthapally	Newland	11KV	Patancheru	11.20	13.30	02.10		B/D Due to Jumper Cut	-
2		Gundla Machnoor	Industrial	11KV	Patancheru	10.10	13.00	02.50		B/D Due to Insulator Failure	-
1	SDP	Thotapally	Mallampally	11KV	Husnabad	15.00	16.00	01.00		Insulator fail	-
2		Akkannapet	Fakkirnayak thanda	11KV	Husnabad	07.25	16.40	09.15		Line cut	-
3		Pandilla	Kuchanpally	11KV	Husnabad	19.30	23.59	04.29		Heavy gale and wind	-
4		Mustyala	Chunchanakota	11KV	Husnabad	09.30	11.40	02.10		Disk fail	-
5		Markook SS	Markook Agl Feeder LC:11754 (Bhaskar CL)	11KV	Gajwel	17.58	19.15	01.17		Jumper Open	-
6		Ganeshpally SS	Angadikistapur LC:32345 (Suresh CL)	11KV	Gajwel	15.00	16.10	01.10		HT line to LT line Touching	-
7		Marpadaga SS	Sirsinagandla AGL LC:2704 (Raheem JLM)	11KV	Gajwel	18.20	19.50	01.30		Disk Fail	-
8		Marpadaga SS	Marpadaga AGL II	11KV	Gajwel	18.00	23.59	05.59		Reason Not found	-
9		Musathabad Chowrasta	Raghvendra Nagar	11KV	Siddipet	18.50	19.15	00.25		B/D for Due to Bird	-
10		Musathabad Chowrasta	Gadicherlapally	11KV	Siddipet	02.30	06.30	04.00		B/D for 11KV line Phase to phase	-
11		Laxmidevipally	Laxmidevipally	11KV	Siddipet	14.45	16.10	01.25		B/D for Copper patti problem	-
12		Chellapur	Rajakkapet	11KV	Siddipet	17.27	18.36	01.09		B/D for Due to bird LC No.3002	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Gachibowli	Gopanpally	11KV	Gachibowli	20.10	22.00	01.50	BD	11KV AB switch insulator failed in SS	-
2		Puppalaguda	Alkapuri Colony	11KV	Ibrahimbagh	18.15	20.46	02.31	BD	11KV Pin insulator failed at Road No.28	-
1	RR N	Laxmapur	Laxmapur	11KV	Medchal	17.50	19.00	01.10	EL	11KV Pin Insulator failed and replaced at Laxmapur	-
1	RR E	Moula-Ali	Gayatri Nagar	11KV	Sainikpuri	19.48	21.23	01.35		11Kv Pin Insulator failed at Sadulla Nagar (Artisan Raju/Venkataiah)	-
2		Vasanthapuri	Raghavendra	11KV	Sainikpuri	22.06	23.26	01.35		11KV Disc Failed at Balaji Function Hall	-
1	HYD N	Clock Tower	Natraj	11KV	V	20.35	21.55	01.20	EL,OL	Cable End Kit fault at BSNL Office	-
2		R.P.Nilayam	Raithu Bazar	11KV	C-VI	13.15	14.25	01.10	EL,OL-Y&Bph	Cable jumper cut at ITI College	-
3		New Bowenpally	Raju Colony	11KV	VI	21.15	22.25	01.10	EL	Tree branches fallen on lines at Raju Colony	-
4		Lalaguda	Vijayapuri	11KV	V	21.30	23.10	01.40	EL,OL-Bph	UG Cable fault at Metro Station	Arranged B/F on 11KV Chenna Reddy Nagar feeder
1	HYD S	Kandikal Gate	Rakshapuram	11KV	III	05.36	07.10	01.34	EL	Cable End Kit failed at Shivalayam Temple (4Nos.DTR's kept off)	-
2		Asmangadh	Shiva Ganga	11KV	VIII	22.48	00.57	02.09	EL,OL-Rph	-----	Arranged B/F on 11KV P & T Colony feeder
1	HYD C	Bathkammakunta	Ayyappa Temple	11KV	II	00.20	01.55	01.35	OL	Pin Insulator flash over at Old Satya Sai School	-
2		Erramanzil	Jaffer Ali Bagh	11KV	I	20.15	22.00	01.45	EL	DTR fault at Jaffer Ali Bagh	-
3		Public Garden	Nampally Raliway Station	11KV	I	21.11	23.40	02.29	EL,OL-Rph	I/C Cable fault	Arranged B/F on 11KV Gunfoundry fdr
4		Vittalwadi	Gandhi Kuteer	11KV	II	23.00	00.45	01.45	EL	No Visible Fault (2No. DTR's Kept Off)	-