

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	7	1	7	1	7			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	19	1	19	1	19			
	Total	606	3055	2	29	2	29	2	29	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	12	2	12	2	12			
2	NLG	144	988		20		20		20			
3	MDK	107	933	2	8	2	8	2	8			
4	SDPT				15		15		15			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	55	4	55	4	55	0	0	
	Grand Total	1082	6468	6	84	6	84	6	84	0	0	

## TSSPDCL - LMRC / Corporate office

Date: 15.07.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shanthinagar	33KV	Gadwal	19.58	21.25	01.27	E/L	Tree Fallen on the Line Near Shathinagar	Shanthinagar	No
2		Wanaparthi	Rajapur	33KV	Wanaparthi	21.56	22.50	00.54	E/L	Red Hot Absured	Rajapur	Alternate Supply Arragned to 33KV Koadir Feeder at 22:50Hrs
1	MDK	Gummadidala	GPSS-I	33KV	Patancheru	16:45	18:05	1:20		Lightening arrestor failure	GPSS-I	No
2		Zaheerabad	Old Allana	33KV	Zaheerabad	12.30	15.10	02.40		Jumper cut	Old Allana	No
1	RR N	132KV LGM Pet	LGM Pet	33KV	Medchal	17:30	18:36	1:06		Line AB Swtich opened at Monsanto Company, Tree fallen on the 33KV line	LGM Pet	No
1	HYD N	132KV Asifnagar	Alluri Seetaramaraju	33KV	Asifnagar	02.45	03.00	00.15	OL	Tripped on OL RYB Phases, Due to End Kit failed and replaced at 132kV Asif nagar SS.	Alluri Seetaramaraju	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Serivenkatapur	Suraram	11KV	Mahabubnagar	08.12	10.56	02.44		11KV Disc failure at suraram	No
2		Marrikal	Chakalapally	11KV	Jadcherla	02.25	08.55	06.30		11 KV wire cut near Chakalapally	No
3		Jadcherla	Burgupally	11KV	Jadcherla	05.25	09.00	03.35		11 KV Insulator fail near Burgupally	No
4		Midjil	Munнанur	11KV	Jadcherla	12:50	15:20	2:30		11 KV Insulator fail near Munнанur	No
5		Lokirew	R.C.Pur	11KV	Jadcherla	3:00	7:48	4:48		11 KV Insulator fail near R.C.Pur	No
6		Karkonda	Fathepur	11KV	Jadcherla	2:14	8:37	6:23		11 KV wire cut near Guvulagadda thanda	No
7		Nawabpet	Town	11KV	Jadcherla	11:40	14:00	2:20		11 KV Insulator fail near Nawabpet	No
8		Gundumal	Gundumal Agl	11KV	Narayanapet	8:30	11:30	3:00		Disc problem	No
9		Kosgi	Nacharam	11KV	Narayanapet	4:15	6:45	2:30		Due to Rain	No
10		Damargidda	Sadnapur	11KV	Narayanapet	2:00	10:18	8:18		11 kv feeder line cutover due to tree fall.	No
11		Ekaspur	Chittanur	11KV	Narayanapet	8:00	9:00	1:00		11kv Conductor cut due to gail & wind	No
12		Ekaspur	Ekaspur	11KV	Narayanapet	05.00	16.50	11.50		Disc problem	No
1	NLG	Edulur	Garlabaigudam	11KV	Nalgonda	8:00	10:00	2:00	E/L	11KV Jumper cut	No
2		Turkapally	M.Gowraram	11KV	Nalgonda	07.20	09.00	01.40	E/L	11KV Insulator failed	No
3		Koppole(K)	Kopolu	11KV	Nalgonda	06.00	07.30	01.30	E/L	11KV Jumper cut	No
4		Agamothkur	Agamothkur	11KV	Miryalaguda	03.25	05.25	02.00	E/L	Insulater failed	No
5		Tadakamalla	Molkapatnam	11KV	Miryalaguda	08.10	10.45	02.35	E/L	Jumper cut	No
6		Kothagudem	Kothagudem	11KV	Miryalaguda	10.05	11.05	01.00	E/L	Insulater failed	No
7		Muppam	Mothkur	11KV	Miryalaguda	10.00	11.30	01.30	E/L	Disc failed	No
8		Damarcherla	Bothalapaalem	11KV	Miryalaguda	05.05	08.00	02.55	E/L	Insulater failed	No
9		Jalalpuram	Velishala	11KV	Suryapet	06.00	09.00	03.00	E/L	Conductor snapped	No
10		Penpahad	S R Palem	11KV	Suryapet	10.30	13.20	02.50	OL	Insulator failed	No
11		Phanigiri	Anantharam	11KV	Suryapet	06.15	08.30	02.15	E/L	Jumper cut	No
12		Mattampally	Allpuram	11KV	Huzurnagar	12.20	14.00	01.40	EL	11 KV LINE SNAPPED	No
13		Janpahad	Shunyapahad	11KV	Huzurnagar	11.40	13.00	01.20	EL	11 KV JUMPER CUT	No
14		MT.Pally	Mulkalapally	11KV	Bhongir	12.30	15.20	02.50	EL/OL	11kv Insulator Failed near Mulkalapally Village	No
15		Peddathanda	Peddathanda	11KV	Bhongir	04.45	08.10	03.25	EL/OL	100 kva DTR Failed near Peddathanda village.	No
16		NG.Bandal	Gandamalla	11KV	Bhongir	14.35	15.10	00.35	EL/OL	11KV Disc Failed near Indireyal Village	No
17		Bibinagar	Saketh india	11KV	Bhongir	02.00	07.30	05.30	EL/OL	11 kv Insulator failed 11 kv Jumper snapped & Bird fallen at line near FCI Godam Bibinagar	No
18		B.Ramaram	Malyala	11KV	Bhongir	04.50	10.30	05.40	EL/OL	11kv Disc Failed near Kondareddy well	No
19		Athmakur	Koratikal	11KV	Bhongir	04.10	11.00	06.50	EL/OL	11kv Insulator Failed near Athmakur Village	No
20		Yennaram	Kakkireni	11KV	Choutuppal	6:30	8:30	2:00	EL/OL	11 kv Line snapped near Kakkireni village.	No
1	MDK	Sadasivapet	TSM	11KV	Sangareddy	16:18	18:15	1:57		Insulator Failure	No
2		Sadasivapet	Kambalapally	11KV	Sangareddy	16.27	18.30	02.03		Insulator Failure	No
3		EPIP-I	Chitrakoot	11KV	Sangareddy	12.35	13.15	00.40		Conductor snapped	No
4		Gummadidala	Agrobell	11KV	Patancheru	12.50	13.40	00.50		Insulator Failure	No
5		SOL	Markwell	11KV	Patancheru	12.55	13.40	00.45		Tree branches fallen on the line	No
6		Bollaram-I	Town-I	11KV	Patancheru	22.46	23.30	00.44		Conductor snapped	No
7		Bollaram-I	Sulaxshana-I	11KV	Patancheru	19.30	22.03	02.33		Conductor snapped	No
8		Bollaram-I	Kythan	11KV	Patancheru	19:30	22:40	3:10		Conductor snapped	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Markook SS	Markook Agl	11KV	Gajwel	11:37	11:44	0:07		Insularer failed	No
2		Raipole SS	Thimmakkapally	11KV	Gajwel	14:40	17:00	2:20		AB Switch works	No
3		Ramsagar SS	Ramsagar	11KV	Gajwel	15:40	17:00	1:20		Insularer failed	No
4		KATKUR	RAMAVARAM & MALLARAM	11KV	Husnabad	15.30	16.00	00.30		Tree failed	No
5		THOTAPALLY	THOTAPALLY	11KV	Husnabad	13.32	15.52	02.20		Insulator failure	No
6		THOTAPALLY	MALLAMPALLY	11KV	Husnabad	14.19	16.35	02.16		Tree fallen on the line	No
7		AKKANAPET	PAKILNAYAK THANDA	11KV	Husnabad	14.30	15.00	00.30		Jumper cut	No
8		DHARMARAM	Nandaram & Potharam(J)	11KV	Husnabad	12.00	14.45	02.45		LV -II Tripping coil problem	No
9		REGULAPALLY	REGULAPALLY	11KV	Husnabad	16.10	18.20	02.10		Due to rainfall	No
10		Akunoor	Akunoor Agl	11KV	Husnabad	14.20	15.40	01.20		Insulator failure	No
11		Dhoolmitta	Lingapur	11KV	Husnabad	13.50	15.10	01.20		INSULATOR FAILURE	No
12		Rebarthy	Ladnoor	11KV	Husnabad	13.45	14.40	00.55		DUE TO RAINFALL	No
13		Marmamula	Dharmaram	11KV	Husnabad	16.00	17.37	01.37		Insulator failure	No
14		Marmamula	Salakpoor	11KV	Husnabad	18.24	19.30	01.06		Insulator failure	No
15		Narmetta	Narmetta	11KV	Siddipet	18:05	19:20	1:15		Tree branches fallen on the 11 KV Line)	No
1	RR S	Mathrusri Nagar	Mahava Nagar	11KV	Gachibowli	16:50	17:59	1:09		11KV Pin insulator failure at SBI bank	No
2		Kokapet	Gonsha Hills	11KV	Ibrahimbagh	17.05	19.00	01.55		11KV Disc failed at Occian Park	No
1	RR N	Subhash Nagar	Saibaba Nagar	11KV	Medchal	12:35	13:34	0:59		11KV Pin Insulator failed at Srinidhi Apartment, Saibaba Nagar	No
2		Subhash Nagar	Meenakshi	11KV	Medchal	13.47	15.02	01.15		11KV Pin Insulator failed at Srikara Nilayam Apartment	No
3		Subhash Nagar	Gayatri Nagar	11KV	Medchal	14.59	15.49	00.50		Tree fallen on the 11KV Line at Sai Apartment, Gayatri Nagar	No
4		Jagathgirutta	Shirdi Hills	11KV	Medchal	15.35	18.00	02.25		Breaker Mechanical Problem and rectified in SS ( Alternate supply arranged from Maqdoom Nagar Feeder )	No
5		Kandlakoya	Kandlakoya	11KV	Medchal	01.15	02.30	01.15		11KV Line AB Switch opened near Gubba company (Tree Fallen on 11KV Line )	No
6		Laxmapur	Narayanpur	11KV	Medchal	06.30	09.50	03.20		HG fuse Insulator failed at Deepa Reddy Thota	No
7		Laxmapur	Laxmapur	11KV	Medchal	11:54	13:05	1:11		11KV Pin Insulator failed at Banjarla Bhavi	No
1	RR E	Uppal	Nava Bharat	11KV	Habsiguda	21:50	23:40	1:50		11KV HG Fuse Insulator failed near Mamoj packing Company	No
1	HYD N	Tirumalagiri	Officers Colony	11KV	C-VI	01.10	03.30	02.20	EL,OL-R&Yph	CT PT failed at K.V.School, R.K.Puram	No
2		R.P.Nilayam	Venkatapuram	11KV	C-VI	14:09	15:10	1:01	EL,OL	Tree branches fallen on lines at R.C.Colony	No
3		New Bowenpally	Police Quarters	11KV	VI	13:55	15:20	1:25	EL,OL	Jumper cut at Bharath Lodge	No
4		Marredpally	Military Hospital	11KV	C-VI	14:20	15:35	1:15	EL,OL-Bph	Tree branches fallen on lines at Military	No
5		New Bowenpally	Shobala Colony	11KV	VI	12:35	16:05	3:30	EL,OL	Cable Jumper cut at Shobana Colony	No
6		Marredpally	R.K.Puram	11KV	C-VI	14:45	16:10	1:25	EL,OL-Rph	Tree branches fallen on lines at Military Area	No
7		Prashanth Nagar	Prashanth Nagar	11KV	VI	12:30	17:15	4:45	EL,OL-Rph	Pin Insulator flash over at Amma Mess	No
8		Prashanth Nagar	Shakthipuram	11KV	VI	21:00	0:05	3:05	EL	Cable jumper cut & Pin Insulator flash over at Shakthipuram	Added partial loads on 11KV Sony Complex feeder
1	HYD S	Asmangadh	Saraswathi Nagar	11KV	VIII	22.05	01.05	03.00	All Indication	No Visible Fault	Arranged B/F on 11KV G.A Bank Colony for

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD C	A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	13.42	15.30	01.48	EL	Tree branches fallen on lines at Mehdipatnam	No
2		Hussain Sagar	Maruthi Nagar	11KV	I	13.15	15.25	02.10	EL,OL	Pin Insulator flash over at Raju Nagar	No
3		ITI Mallepally	Zaheera Masjid	11KV	VII	14.02	15.40	01.38	EL,OL	Pin Insulator flash over at China Bazar	No
4		Industrial Area	D.D.H	11KV	II	16.40	17.40	01.00	EL,OL	O/G AB Switch Jumper cut at SS	No
5		A.S.R.Raju Nagar	L.I.C Office	11KV	VII	17.00	18.00	01.00	EL	Tree branches fallen on lines at Saibaba Community Hall	No
6		Gudimalkapur	Murad Nagar	11KV	VII	16.30	18.15	01.45	EL,OL-Rph	Tree branches fallen on lines at Murad Nagar & cut Jumper, AB Switch fault at Miraz Hotel	No
7		S.D.Hospital	Crescent Hospital	11KV	VII	16.20	18.30	02.10	EL,OL-R&Bph	Cable jumper cut at NMDC	No
8		Asif Nagar	Kakatiya Nagar	11KV	VII	17.11	18.34	01.23	EL,OL-Rph	Conductor snapped at Kakatiya Nagar Park	No
9		A.S.R.Raju Nagar	G.H.M.C	11KV	VII	17.20	18.58	01.38	OL-Rph	End Kit failed at GHMC Community Hall	No
10		Fever Hospital	Barkathpura Bus Depot	11KV	II	20.30	22.00	01.30	EL,OL-Rph	Pin insulator flash over at Kachiguda Junior College	No