

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | 2 | | 2 | | 2 | | | |
| 6 | RR(N) | 54 | 550 | | 3 | | 3 | | 3 | | | |
| 7 | RR(E) | 168 | 403 | | 2 | | 2 | | 2 | | | |
| 8 | Hyd | 194 | 1044 | | 3 | | 3 | | 3 | | | |
| | Total | 606 | 3055 | 0 | 10 | 0 | 10 | 0 | 10 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 2 | 12 | 2 | 12 | 2 | 12 | | | |
| 2 | NLG | 144 | 988 | | 7 | | 7 | | 7 | | | |
| 3 | MDK | 107 | 933 | 2 | 1 | 2 | 1 | 2 | 1 | | | |
| 4 | SDPT | | | | 10 | | 10 | | 10 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 4 | 30 | 4 | 30 | 4 | 30 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 4 | 40 | 4 | 40 | 4 | 40 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 16.07.2020

Circle-wise 33KV Breakdowns

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MBNR | Balanagar | Chinchode | 33KV | Jadcherla | 16.30 | 18.35 | 02.05 | OL | 1Phase conductor cut near by 132KV SS Balanagar Road side | | NO |
| 2 | | Kothur | Kothur | 33KV | Rajendrnagar | 06.55 | 09.20 | 02.25 | OL | CT & PT failed at Prince Pipe Company | | NO |
| 1 | MDK | Gummadidala | GPSS-1 | 33KV | Patancheru | 15.25 | 17.20 | 01.55 | | BD due Pin binding failed | | - |
| 2 | | Singoor | Mission Bhageeratha | 33KV | Jogipet | 00.00 | 11.20 | 11.20 | | BD due to Tree fallen on the line | | - |

Circle-wise 11KV Breakdowns

Date: 16.07.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|---|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Lokirev | Lingampally | 11KV | Jadcherla | 10.34 | 14.29 | 03.55 | | 11kv Phase To PhaseNear Lingampally (Vi). | - |
| 2 | | Jadcherla | Kothamolgara | 11KV | Jadcherla | 12.46 | 14.30 | 01.44 | | HT/Lt Near Kotha Kappeta(Vi). | - |
| 3 | | Gundumal | Gundumal Agl | 11KV | Narayanapet | 12.02 | 13.30 | 01.28 | | 11 KV Phase to Phase | - |
| 4 | | Kosgi | Mission Bhagiratha | 11KV | Narayanapet | 09.30 | 16.30 | 07.00 | | Cable Problam on the Consummer side(CT&PT set) | - |
| 5 | | Maddur | Pallerla | 11KV | Narayanapet | 11.17 | 11.52 | 00.35 | | Disc Problem | - |
| 6 | | Maddur | Dorepally | 11KV | Narayanapet | 18.15 | 19.35 | 01.20 | | Disc Problem | - |
| 7 | | Mominapur | Appireddypally | 11KV | Narayanapet | 02.00 | 10.30 | 08.30 | | DC Fail | |
| 8 | | Damargidda | Bapanpalli | 11KV | Narayanapet | 15.35 | 21.24 | 05.49 | | insulator failed | |
| 9 | | kyatanpally | ottugundla | 11KV | Narayanapet | 17.00 | 19.00 | 02.00 | | 11kv disc problem | |
| 10 | | Eklaspur | jinnaram | 11KV | Narayanapet | 07.00 | 08.20 | 01.20 | | Disc problem | - |
| 11 | | Eklaspur | Chittanoor | 11KV | Narayanapet | 07.30 | 10.00 | 02.30 | | 3 phase line problem | - |
| 12 | | kondapur | Hanmanpally | 11KV | Narayanapet | 11.20 | 13.35 | 02.15 | | LT line repair at DTR | - |
| 1 | NLG | Phanigiri | Etoor | 11KV | Suryapeta | 05.00 | 08.40 | 03.40 | E/L | Insulator failed | - |
| 2 | | Bethavolu | Chennarigudem | 11KV | Huzurnagar | 06.30 | 08.30 | 02.00 | EL | 11 KV LINE SNAPPED | - |
| 3 | | Siripuram | Vallapuram | 11KV | Huzurnagar | 05.00 | 07.30 | 02.30 | EL | 11 KV JUMPER CUT | - |
| 4 | | Rajupeta | Jonnagaddalagudem | 11KV | Nalgonda | 05.00 | 08.00 | 03.00 | EL | 11KV Jumper cut | - |
| 5 | | S.Lingotam | Lingojigudem | 11KV | Choutuppal | 01.33 | 08.49 | 07.16 | EL/OL | 11 kv Insulator failed at Kaluva katta near Lingoigudem village. | - |
| 6 | | Juloor | Kapraipally | 11KV | Choutuppal | 03.30 | 10.45 | 07.15 | EL/OL | 11 kv Line snapped near Juloor village. | - |
| 7 | | Marriguda | Vattipally | 11KV | Devarakonda | 17.00 | 17.40 | 00.40 | EL/OL | 11 KV Jumper Cutt | - |
| 1 | MDK | Patancheru Town | Town Indl. | 11KV | Patancheru | 02.00 | 04.20 | 02.20 | | BD due to Jumper cut | - |
| 1 | SDPT | Kodakandla SS | Kukunoorpally Feeder LC: 19796 (Satyanarayana LM) | 11KV | Gajwel | 08.15 | 09.00 | 00.45 | | Tree Branch Fallen | - |
| 2 | | Karkapatla SS | Karkapatla AGL LC:30272 (Hanumanthu LM) | 11KV | Gajwel | 15.15 | 16.00 | 00.45 | | AB switch Repair | - |
| 3 | | Ganeshpally SS | Ganeshpally Agl LC:32347(suredh CL) | 11KV | Gajwel | 15.09 | 16.25 | 01.26 | | DT R Repair | - |
| 4 | | Damarakunta Ss | DamarakuntaFeeder LC:30825 (Hanumanthu LM) | 11KV | Gajwel | 06.30 | 11.33 | 05.03 | | Pole Damaged | - |
| 5 | | Bandaram Ss | Bandaram Feeder LC:38322 (Narender LI) | 11KV | Gajwel | 08.50 | 13.05 | 04.15 | | Disk Fail | - |
| 6 | | Anajipur Ss | Manthur LC:1575 (V. Narsimlu LM) | 11KV | Gajwel | 17:26 | 18:21 | 00:56 | | Jumper Out | - |
| 7 | | Mustabad X-Road | Gadicherlapally | 11KV | Siddipet | 15.35 | 16.10 | 00.35 | | B/D - Face to face | - |
| 8 | | Mustabad X-Road | Gadicherlapally | 11KV | Siddipet | 19.25 | 19.55 | 00.30 | | B/D - Face to face | - |
| 9 | | Rebarthy | Ladnoor | 11KV | Husnabad | 20.30 | 21.05 | 00.35 | | 100 KVA DTR Failed in line | - |
| 10 | | Bejjanki | RWS | 11KV | Husnabad | 07.30 | 07.50 | 00.20 | | Bird Fell on line | - |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---|
| 1 | RR S | Lanco Hills | Khajaguda | 11KV | Gachibowli | 02.08 | 03.18 | 01.10 | BD | 11KV Disc failed at Venugopal Temple | - |
| 2 | | Nanakramguda | Gulfview | 11KV | Gachibowli | 04.08 | 05.38 | 01.30 | BD | AB Cable Endkit failed at Gulfview | - |
| 1 | RR N | Nizampet | Bhavyas | 11KV | Medchal | 05.55 | 07.10 | 01.15 | EL | 11KV Endkit failure near More super market | - |
| 2 | | Petbasheerabad | Satyam Enclave | 11KV | Medchal | 01.00 | 02.42 | 01.42 | EL/OL | 11KV Jumper cut and replaced at Arunodhaya Paper Board | - |
| 3 | | Keshavaram | Dairy | 11KV | Medchal | 13.15 | 18.05 | 04.50 | EL | 11KV Pole damaged by Car & replacement at Keshavaram Village | - |
| 1 | RR E | Nacharam | Nile | 11KV | Habsiguda | 07.50 | 08.39 | 00.49 | | 11KV Lighting erector failed,Incoming side Jumper & 3Nos HG Fuse failed at Nile Company(Dedicated Feeder) | - |
| 2 | | Nacharam | Stallion Tyres | 11KV | Habsiguda | 07.50 | 10.18 | 02.28 | | 3Nos HG fuse fail & Line snapped of Metal guard & CT/PT changed ,3Nos HG fuse gone 11kv jumper Polymer company & 3Nos HG fuse gone & Incoming jumper fail of orden craft company | - |
| 1 | HYD N | H.A.L | Samrat | 11KV | Bowenpally | 01.53 | 03.07 | 01.14 | OL-R&Yph | No Visible Fault | Arranged B/F on 11KV Raju Colony feeder |
| 2 | | R.P Nilayam | Venkatapuram | 11KV | Bowenpally | 16.51 | 18.12 | 01.21 | OL-R&Bph | Tree branches fallen on lines near Railway Track | - |
| 1 | HYD S | Santosh Nagar | Raza Nagar | 11KV | Asmangadh | 12.12 | 14.29 | 02.17 | EL,OL | 2No. Line AB Switch Jumpes cut at Raza Nagar | - |