

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		6		6		6			
2	NLG	144	988		7		7		7			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	23	1	23	1	23	0	0	
	Grand Total	1082	6468	1	24	1	24	1	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Jharasangam	33KV	Zaheerabad	12.02	15.00	02.58	BD due to Jumper cut	BD due to Jumper cut	Jharasangam	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 17.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Nacharam	11kv	Narayanapet	16.40	18.00	01.20		Tree branchase follen on the line	-
2		Salkarpet SS	Gandeed Town	11kv	Narayanapet	03.20	04.20	01.00		Tree branchase follen on the line	-
3		Mogulmadka	Annasagar	11kv	Narayanapet	14.50	18.34	03.44		11KV Line cut due to gail	-
4		Marikal	Elligandla	11kv	Narayanapet	07.22	08.39	01.17		Tree fall in village	-
5		Narayanpet	Satyasai	11kv	Narayanapet	14.50	16.00	01.10		Tree fall on 11 KV line near new gunj	-
6		Eklaspur	Karmanoor	11kv	Narayanapet	06.00	08.20	02.20		Disk failure	-
1	NLG	Kodur	Loyapally	11kv	Suryapet	03.00	06.15	03.15	E/L	Jumper cut	-
2		Palakeedu	Bothalapalem	11kv	Huzurnagar	04.30	07.00	02.30	EL	11 KV LINE SNAPPED	-
3		Munagala	Nelamarry	11kv	Huzurnagar	06.00	08.15	02.15	EL	11 KV JUMPER CUT	-
4		Thipparthi	Thipparthi	11kv	Nalgonda	02.00	04.00	02.00	EL	11 KV Line Jumper Cut	-
5		Rajupet	Jonnagaddalagudem	11kv	Nalgonda	10.40	11.40	01.00	EL	11 KV Line Jumper Cut	-
6		Sharajipet	Sharajipet	11kv	Bhongir	10.30	13.55	03.25	EL/OL	SS-7 25kva DTR Failed	-
7		Azeempet	Azeempet	11kv	Bhongir	03.00	11.20	08.20	EL/OL	100 kva DTR Failed near Azeempet village & 2 no's 11 kv Insulators failed at SS- 7 near Azeempet village.	-
1	MDK	Sangareddy Rural	P.R.Pally	11kv	Sangareddy	15.28	16.30	01.02		BD due to 11kv Disk failed	-
2		Sadasivapet	Town -II	11kv	Sangareddy	12.50	13.25	00.35		BD due to Tree branches fallen on the line	-
3		Patancheru Town	MIA-II	11kv	Patancheru	08.25	09.50	01.25		BD due to Jumper cut	-
1	SDPT	Mustabad X-Road	Gadicherlapally	11kv	Siddipet	09.55	12.15	02.20		B/D HT/LT Line problem LC No.2120	-
2		Chinnagudavelly	Chinnagundavelly	11kv	Siddipet	13.05	14.40	01.35		B/D	-
3		Munigadapa SS	Mandapur Feeder	11kv	Gajwel	15.10	18.10	03.00		Cunductor Cut	-
4		Kodakandla SS	Kukunoorpally Feeder	11kv	Gajwel	08.15	09.00	00.45		Tree Branch Fallen	-
5		Mettu SS	Peddamasanpally Feeder	11kv	Gajwel	20.00	20.23	00.23		11 KV Jumper Cut	-
6		Bejjanki	Muthannapet	11kv	Husnabad	12.15	13.15	01.00		Due to tree branch fallen on line, same rectified	-
7		Begumpet	Laxmipur	11kv	Husnabad	05.50	08.55	03.05		Due to line snapped, same rectified.	-
1	HYD C	Indira Park	Kawadiguda	11kv	Azamabad	20.53	22.15	01.22	EL,OL	No Visible Fault	At 21:07Hrs partial fdr charged (20/50Amp)