

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988	1	11	1	11	1	11			
3	MDK	107	933		2		2		2			
4	SDPT				18		18		18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	33	2	33	2	33	0	0	
	Grand Total	1082	6468	3	34	3	34	3	34	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shantinagar-1	33KV	Gadwal	08.10	09.43	01.33	E/L&O/L	Tree Fallen on the Line at Ramapuram(V)		NO
1	NLG	Narkatpally	Nemmani	33KV	Nalgonda	13.55	15.08	01.13	E/L	33KV Insulator failed, replaced		-
1	RR N	132KV Medchal	33KV Steel Mills	33KV	Medchal	09.00	13.51	04.51	BD	33KV Line cut and replaced at IDA Medchal altarenate arranged at 9:10 from GP Pallyy-1		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 20.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kandoor	Choudaipally	11KV	Jadcherla	03.45	09.45	06.00		11KV Insulator Failure Near Sunkarampally(V)	-
2		Teegalapally	Teegalapally Agl	11KV	Jadcherla	01.05	07.40	06.35		11KV Jumper Cut Near Teegalapally(V)	-
1	NLG	Eduloor	Parada	11KV	Nalgonda	00.05	07.50	07.45	E/L	11KV Jumper cut	-
2		Kethepally	Kasanagode	11KV	Nalgonda	06.20	09.15	02.55	O/L	11KV Jumper cut	-
3		Kethepally	Inupamula	11KV	Nalgonda	07.00	08.30	01.30	E/L	Tree branches fallen on line	-
4		Palem	Bopparam	11KV	Nalgonda	03.15	08.30	05.15	E/L	Tree branches fallen on line	-
5		Palem	Ogodu	11KV	Nalgonda	03.15	08.30	05.15	E/L	Tree branches fallen on line	-
6		Palem	Palem	11KV	Nalgonda	03.15	08.30	05.15	E/L	Tree branches fallen on line	-
7		Bopparam	M.Kothagudem	11KV	Suryapet	02.10	06.30	04.20	E/L	Insulator flashover	-
8		Mattampally	Allpuram	11KV	Huzurnagar	12.20	13.10	00.50	EL	11 KV LINE SNAPPED	-
9		Peddathanda	Pallepahad	11KV	Bhongir	09.00	12.45	03.45	EL/OL	11kv Disc Failed near MothiramThanda	-
10		Kondamadugu	Anand agro	11KV	Bhongir	07.45	10.30	02.45	EL/OL	11kv Disc Failed near Kondamadugu Vilage	-
11		Kapraipally	Kapraipally	11KV	Bhongir	04.00	10.20	06.20	EL/OL	11 kv Line snapped near Kapraipally village out side	-
1	MDK	EPIP-II	Padmapower	11KV	Sangareddy	17.15	20.05	02.50		BD due to Disk failed	-
2		EPIP-III	Tychy Diecast	11KV	Sangareddy	17.35	19.10	01.35		BD due to Tree branches fallen on the line	-
1	SDPT	Husnabad	Pandilla & Malapally	11KV	Husnabad	08.35	11.35	03.00		EL&OL tripping	-
2		koheda	Sriramulapally	11KV	Husnabad	05.30	07.30	02.00		Conductor snapped	-
3		Guruvannapet	Posanpally	11KV	Husnabad	17.30	18.40	01.10		Insulator fail	-
4		Bekkal	Kutigal	11KV	Husnabad	06.05	08.20	02.15		Bird fallen in line	-
5		Bekkal	Kondapur	11KV	Husnabad	00.00	08.30	08.30		Insulator fail	-
6		Mustabad X Road	Hanuman Nagar	11KV	Siddipet	16.00	16.25	00.25		Disk fail	-
7		Munigadapa	Mandapur	11KV	Gajwel	08.15	12.20	04.05		Insulator fail	-
8		Pregnapapur	Akkaram	11KV	Gajwel	07.40	08.04	00.24		Insulator fail	-
9		Pregnapapur	Industrial	11KV	Gajwel	14.28	16.15	01.47		Line cut	-
10		Kodakandla	Kulunoorpally	11KV	Gajwel	00.01	08.30	08.29		Tree Breachs fallen on line	-
11		Kodakandla	Kulunoorpally	11KV	Gajwel	18.30	23.59	05.29		Tree Breachs fallen on line	-
12		Nacharam	Nacharam	11KV	Gajwel	08.45	11.00	02.15		Line cut	-
13		Nacharam	Madharam	11KV	Gajwel	00.00	00.00	06.00		Tree Breachs fallen on line	-
14		Duddeda	Duddeda	11KV	Gajwel	00.00	18.00	18.00		Tree Breachs fallen on line	-
15		Thipparam	Thipparam	11KV	Gajwel	05.30	08.40	03.10		Line cut	-
16		Thipparam	Erravally	11KV	Gajwel	05.30	11.50	06.20		Insulator fail	-
17		Mettu	Mettu industrial	11KV	Gajwel	06.00	08.30	02.30		Insulator fail	-
18		Godugupally	Godugupally	11KV	Gajwel	08.35	12.05	03.30		disk failed	-
1	RR E	Saketh	Jawahar Nagar	11KV	Keesara	04.40	06.00	01.20		Line patrolling but no visible fault	-