

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	2	3	2	3	2	3			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	2	5	2	5	2	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	12	5	12	5	12			
2	NLG	144	988		12		12		12			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT			2	9	2	9	2	9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	8	36	8	36	8	36	0	0	
	Grand Total	1082	6468	10	41	10	41	10	41	0	0	

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Chinnamaroor	Weepangandla	33kv	Wanaparthi	06.40	07.10	00.30	E/L	Due Rain & Wind, Weepangandla Feeder Loads Tag on to 33KV Kalwarala Feeder	Weepangandla	-
2		Chinnamaroor	Velgonda	33kv	Wanaparthi	18.55	19.35	00.40	E/L	CT Blast Break Down Alternate Supply taken to 33KV Aiyawaripally Feeder at 19:35Hrs	Velgonda	-
3		Balanagar	Hari OM	33kv	Jadcherla	04.50	05.45	00.55	E/L	No Visbule Fault	Hari OM	-
4		Marikal	Koukuntla	33kv	Narayanapet	04.20	09.05	04.45	E/L	Tree Fallen on the Line Near at Dasaypally	Koukuntla	-
5		Alampur	Shathinagar-I	33kv	Gadwal	05.10	06.38	01.28	O/L	Tree Fallen on the Line Near at Ramapuram Viilage	Shathinagar-I	-
1	MDK	Kandi	IIT Kandi	33kv	Sangareddy	10.10	14.10	04.00		BD due to Lighting Arrester failed at 132KV SS	IIT Kandi	-
3	SDPT	Habsipur	Ragothampally	33kv	SDPT	14.10	14.45	00.35		B/D Due to Bird	Ragothampally	-
4	SDPT	Habsipur	Thimmapur	33kv	SDPT	15.20	15.40	00.20		B/D Due to Bird near	Thimmapur	-
1	RR N	132KV Malkaram	33KV Ratnalayam	33kv	Medchal	09.00	17.05	08.05	BD	33KV UG Cable end Kit failed and replaced near Shameerpet SS (Time 09:30 alternative Supply Arranged from 33KV LGM Pet feeder 132Kv LGM Pet SS)	33KV Ratnalayam	-
2		132KV Medchal	33KV Keshavaram	33kv	Medchal	17.04	17.51	00.47	BD	Tree Branches removed at Pudur Village	33KV Keshavaram	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 21.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Hanwada	Nainonipally	11kv	Mahabubnagar	09.05	10.20	01.15		11KV Conductor cut at Ebrahimbad	-
2		Hanwada	Buddaram	11kv	Mahabubnagar	08.43	11.54	03.11		11KV Conductor cut at Gudimalkapur	-
3		Hanwada	Munimoksham	11kv	Mahabubnagar	11.30	13.02	01.32		11KV Conductor cut at Kanchempally vagu	-
4		Janampet	Polkampally	11kv	Jadcherla	04.03	06.30	02.27		Tree Follon the line near Thalagadda(v)	
5		Kothamolgara	Karvena	11kv	Jadcherla	10.45	13.30	02.45		11KV Jumper cut near Murthaiha gutta side	
6		Annasagar	Annasagar Rural	11kv	Jadcherla	03.29	06.56	03.27		AB Switch fail near Ravulapally	
7		Kosgi	Bhogaram	11kv	Narayanapet	05.00	08.57	03.57		Break Down Insulator problem	
8		Maddur	Dorepally	11kv	Narayanapet	17.15	19.21	02.06		Break Down Bush road problem near Chinthal dimme	
9		Salkarpet SS	Jangamreddy	11kv	Narayanapet	13.08	17.20	04.12		Break Down Sridhar Land 11KV jumper Insulator Problem	
10		Mohammadabad	Annareddypally	11kv	Narayanapet	09.00	10.00	01.00		Tree fallen on line	
11		Kollampally	Kollampally	11kv	Narayanapet	07.32	10.13	02.41		LT line repair at DTR	
12		Mogalmadka	Mogalmadka Rural	11kv	Narayanapet	16.28	18.05	01.37		3 phase line problem	
1	NLG	Kandagatla	Guttakinda	11kv	Suryapet	03.40	07.50	04.10	E/L	Disc failed	-
2		Garidepally	Kalmalcheruvu	11kv	Huzurnagar	05.00	07.30	02.30	EL	11 KV LINE SNAPPED	-
3		Dirsincherla	Somaram	11kv	Huzurnagar	03.00	06.30	03.30	EL	11 KV JUMPER CUT	
4		Akupamula	K R C Puram	11kv	Huzurnagar	04.50	05.50	01.00	EL	11 KV JUMPER CUT	
5		Nakrekal	Ogodu	11kv	Nalgonda	08.40	09.33	00.53	EL	11KV Jumper cut	
6		Cherkupally	Bandapalem	11kv	Nalgonda	10.30	11.25	00.55	EL	11KV Jumper cut	
7		Nakrekal	Chandanapally	11kv	Nalgonda	13.02	16.50	03.48	EL	Bird Died on the 11 KV Jumper	
8		Thipparthi	Shilarmiyagudem	11kv	Nalgonda	11.30	15.07	03.37	EL	Near Jio Tower 11 KV Jumper Cut	
9		Motakondur	Motakondur Agl	11kv	Bhongir	00.00	06.00	06.00	EL	11kv Insulator Failed near Motakondur Village	-
10		Athmakur	Koratikal	11kv	Bhongir	07.00	08.25	01.25	EL	11kv Disc Failed near Maramma Gudi Koratikal village	-
11		Gundala	Gangapur	11kv	Bhongir	05.40	08.15	02.35	EL	25 KVA DTR Failed at SS- 14 near Gangapur village	-
12		Choutuppal	Chinnakondur	11kv	Choutuppal	06.00	08.30	02.30	EL	11kv Post off Insulator Failed beside Poultry farm near Lingareddy Gudem Road Chinnakondur village	-
1	MDK	Sadasivpet	TSM		Sangareddy	17.05	20.15	03.10		BD due to Jumper cut	-
2		EPIP-III	Ufoam		Sangareddy	05.20	07.25	02.05		BD due to Conductor snapped	
3		EPIP-III	Tychy Diecast		Sangareddy	09.50	10.20	00.30		BD due to tree branches fallen on line	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Siddipet	Nangunoor	Nangunoor	11kv	Siddipet	14.35	17.28	02.53		B/D- AB switch Problem Lcno.3018	
2		Ponnal	Kista Sagar	11kv	Siddipet	15.40	17.00	01.20		B/D- Insulator Failure	-
3		Thadkapally	Venkatapur	11kv	Siddipet	08.21	10.42	02.21		B/D- 11 KV wire cut Lc.no.10624	-
4		Ramancha	Gangapur	11kv	Siddipet	07.35	08.54	01.19		B/D 11 KV disk problem	-
5		Jangapally	Jangapally	11kv	Siddipet	08.25	10.10	01.45		B/D- 11 KV wire cut	-
6		MUNIGADAPA SS	MANDAPUR FEEDER	11kv	Gajwel	01.55	11.12	09.15		JUMPER CUT	-
7		KODAKANDLA SS	KODAKANDLA AGL FEEDER, (LC.NO.9501)	11kv	Gajwel	11.10	11.55	00.45		DISK FAILED	-
8		KONDAPAKA SS	BANDARAM FEEDER	11kv	Gajwel	19.50	20.52	01.02		11KV LINE CUT	-
9		Ramchandrapuram	Ramchandrapur RURAL	11kv	Husnabad	00.00	02.24	02.24		B D , DUE TO DISK FAILURE	-
1	RR N	Aleap	Pragathinagar	11kv	Jeedimetla	04.55	06.00	01.05	BD	Due to rain & stay wire fallin on the 11kv line at Pragathinagar	-
2		Subhash Nagar	Padma Nagar	11kv	Medchal	05.25	08.49	03.24	BD	11KV Pin Insulator failed & Jumper Cut at Andhara Bank & SBI Bank	
3		Kompally	NCL	11kv	Medchal	05.40	07.14	01.34	BD	11KV Pin Insulator failed at Nuziveedu seeds	-
1	HYD N	Road No.13	Road No.1	11kv	X	10.09	11.15	01.06	EL	Cable fault at Road No.1	
2	HYD S	Kandikal Gate	Phool Bagh	11kv	III	13.00	14.15	01.15	EL,OL-Rph	3No. Jumpers cut, I/C Cable fault at Milan Garden, due to Lorry dash to mobile DTR (1No. DTR kept off)	