

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	12	1	12	1	12			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044		17		17		17			
	Total	606	3055	1	38	1	38	1	38	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	6	2	6	2	6			
2	NLG	144	988		13		13		13			
3	MDK	107	933		2		2		2			
4	SDPT			4	41	4	41	4	41			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	62	6	62	6	62	0	0	
	Grand Total	1082	6468	7	100	7	100	7	100	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.07.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Pallerla	33KV	Narayanpet	05.30	08.50	03.20	OL	Insulator failed & Tree fallen on the line	Pallerla	No
2		Alampur	Shanthinagar1	33KV	Gadwal	06.05	07.08	01.03	OL	Tree brannches fallen on the line	Shanthinagar1	No
1	SDPT	Gajwel	Mission Bhageeratha	33KV	Gajwel	6:30	8:30	2:00		Lightening arrester blast	Mission Bhageeratha	No
2		Thukkapur	Mirdoddy	33KV	Gajwel	05.30	14.45	09.15		Insulator Failed	Mirdoddy	No
3		Siddipet	Narayanraopet	33KV	Siddipet	09.35	13.30	03.55		Jumper Cut	Narayanraopet	No
4		Habsipur	Khajipur	33KV	Siddipet	10.10	12.50	02.40	EL	Tree fallen on the line	Khajipur	No
1	RR N	132KV Medchal	Keshavaram	33KV	Medchal	6:25	8:55	2:30		No visible fault	Keshavaram	No

1	RR N	RGK Suraram	Suraram village	11KV	Jeedimetla	7:20	8:50	1:30		Tripped on EL Indication (Due to heavy rain)	No
2		Nizampet	Nizampet	11KV	Kukatpally	06.50	08.15	01.25		Tripped on OL Indication (Due to heavy rain)	No
3		Kompally	Kompally	11KV	Medchal	06.30	06.55	00.25		11KV Line AB Switch Opened at Dulapally X Road (11KV Pin Insulator failed at Central park)	No
4		GP Pally	Apparel Park	11KV	Medchal	08.30	09.30	01.00		Tree Branches fallen on the 11KV Line at Stayon Paper	No
5		Kolthur	Anantharam	11KV	Medchal	07.30	11.25	03.55		11KV Disc failed at IDA Tower, Kolthur	No
6		Medchal	CMR	11KV	Medchal	08.15	09.45	01.30		11KV Jumper cut in SS	No
7		GP Pally	Maisammaguda	11KV	Medchal	09.00	10.20	01.20		Tree branch fallen on the 11Kv Line at Main Campus, Malla Reddy College	No
8		Keshavaram	Adraspally	11KV	Medchal	09.30	11.30	02.00		11KV Pin Insulator failed at near by SS	No
9		Medicity	Pudur	11KV	Medchal	09.35	12.05	02.30		Tree fallen on the 11KV Line at Ganpur Village	No
10		Shameerpet	Nalsar	11KV	Medchal	10.05	11.20	01.15		Tree fallen on the 11KV Line at Celebraty Main gate	No
11		Devarayamjal	Kottapet	11KV	Medchal	10.10	11.20	01.10		Tree fallen on the 11KV Line at DMC (1 DTR off)	No
12		Kistapur	IDA Hanuman	11KV	Medchal	11:02	12:40	1:38		Tree fallen on the 11KV Line at Ravalkole X Roads	No
1	RR E	Moula-Ali	Malkajgiri	11KV	Sainikpuri	7:30	9:00	1:30		Tree branches fallen on 11Kv line at Shivanand Nagar	No
2		Anand Bagh	NMDC	11KV	Sainikpuri	08.20	09.06	00.46		11KV Pin insulotor failed	No
3		Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	06.41	08.52	02.11		Due to heavy rain & Pin Insulator failed	No
4		Vasanthapuri	Sai Ram	11KV	Sainikpuri	07.05	09.59	02.54		11KV Pin insulator failed at Yadav Nagar	No
5		Sainikpuri	Saipuri	11KV	Sainikpuri	08.07	09.08	01.01		Tree fallen on 11Kv line at Bhasker Rao Nagar	No
6		IDA Uppal	Creamline	11KV	Habsiguda	06.32	09.45	03.13		11KV Insulator failed in Creamline Company	No
7		Nacharam	Bhagya Nagar	11KV	Habsiguda	9:10	10:04	0:54		11KV Pin insulator failed at near Prasad Hospital	No
1	HYD N	Seethaphal Mandi	Medi Bawi	11KV	V	06.30	07.50	01.20	EL	No Visible Fault (Due to Rain)	No
2		Marredpally	Nehru Nagar	11KV	C-VI	6:40	8:30	1:50	EL	No Visible Fault (Due to Rain)	At 08:30Hrs partial fdr charged
3		Yellareddyguda	Pragathi Nagar	11KV	X	6:45	8:25	1:40	EL	Tree branches fallen on lines at Shivalayam	No
4		Addagutta	Tukaram Gate	11KV	C-VI	7:17	8:57	1:40	EL	Insulator flash over at Ganga Jamuna Hotel	No
5		Chilkaiguda	P.R.Nagar	11KV	V	7:20	8:50	1:30	EL,OL	DTR fault at Natraj Nagar	No
6		Osm. University	Ravindra Naik Nagar	11KV	V	7:20	8:30	1:10	EL,OL	Tree branches fallen on lines at Ravindra Nagar	No
7		Seethaphal Mandi	Warasiguda	11KV	V	7:20	9:20	2:00	EL	No Visible Fault (Due to Rain)	No
8		R.P.Nilayam	Saraswathi Nagar	11KV	C-VI	8:05	9:12	1:07	EL	Tree branches fallen on lines at Saraswathi Nagar	No
9		Marredpally	Military Hospital	11KV	C-VI	8:20	10:20	2:00	EL,OL	Tree branches fallen on lines at Miilitary Hospital	No
10		Seethaphal Mandi	Seethaphal Mandi	11KV	V	9:00	10:35	1:35	EL,OL-Rph	DTR fault at Chinthai Bai PT	No
11		Tirumalgiri	Mangapuram Colony	11KV	C-VI	10:15	11:45	1:30	EL	No Visible Fault	Arranged B/F on 11KV Ayyappa Ngr & Father Balaiah Nagar feeders
12		Clock Tower	St.Marry's	11KV	V	11:23	12:42	1:19	EL	CT PT fault at Madhava Nursing Home	No
13		Macha Bollarum	Ayyappa Nagar	11KV	C-VI	12:04	16:30	4:26	Tripped AR	2No. DTR's fault at Ayyappa Nagar	No
1	HYD C	Narayanguda	City Central Library	11KV	I	06.40	08.07	01.27	EL	No Visible Fault (Due to Rain)	No
2		Industrial Area	D.D.H	11KV	II	07.20	09.20	02.00	EL	DTR Cable fault at New Apts, Opp: Katta Maisamma, Padma Colony	No
3		Mothi Mahal	Companybagh	11KV	VII	08.18	09.44	01.26	EL,OL-Bph	Cable fault at Companybagh	At 09:12Hrs partial loads arranged B/F on 11KV Pensionpura feeder
4		Langer House	Prashanth Nagar	11KV	VII	9:21	10:33	1:12	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Military Hospital fdr