

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	4	1	4	1	4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	1	9	1	9	1	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	20	1	20	1	20			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	36	2	36	2	36	0	0	
	Grand Total	1082	6468	3	45	3	45	3	45	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.07.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/33KV Singotam	Kudikilla	33KV	Nagarkurnool	17.52	21.30	03.38	E/L	LVs Pull out Due to Relye Problem & Heavy Rain		Alternate Supply Taken to 33KV Chinnapraopally Feeder at 21:30Hrs
1	MDK	R.C.Puram	Ashok Nagar	33KV	Patancheru	09.08	10.40	01.32		BD due to Insulator failed		-
1	RR N	132KV Medchal	33KV Medchal-I	33KV	Medchal	16.01	17.25	01.24	EL/OL	Tree Branches fallen on the 33KV Line at Druva Collage		Alternate supply arranged from 33KV Keshavaram Feeder at 16:45

Circle-wise 11KV Breakdowns

Date: 24.07.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	04.03	06.30	02.27		Tree Follon the line near Thalagadda(v)	-
2		Kothamolgara	Karvena	11KV	Jadcherla	10.45	13.30	02.45		BD 11KV Jumper cut near Murthaiah gutta side	
3		Annasagar	Annasagar Rural	11KV	Narayanapet	03.29	06.56	03.27		BD AB Switch fail near Ravulapally	
4		Gundumal	Gundumal Agl	11KV	Narayanapet	05.15	11.30	06.15		Break Down Due to LT line Cut	
5		Gundumal	Gundumal	11KV	Narayanapet	05.15	09.00	03.45		Break Down Due to Insulator failed near rice mill	
6		Kosgi	Sampally	11KV	Narayanapet	06.10	10.00	03.50		Break Down Due to Insulator failed	
7		Kosgi	Bhogaram	11KV	Narayanapet	16.50	18.40	01.50		Crow fallen on 11 KV Line	
8		Sarjakhapet	Hakeempet	11KV	Narayanapet	05.50	08.10	02.20		Break Down Due to heavy gale and wind	
9		Sarjakhapet	Thogapur	11KV	Narayanapet	05.50	08.10	02.20		Break Down Due to heavy gale and wind	
10		Kothapally	Bhuneed	11KV	Narayanapet	13.20	14.40	01.20		at HT/LT pole HT Line cut and fallen on LT line	
11		Salkarpet SS	Ganded Town	11KV	Narayanapet	04.50	08.40	03.50		Break Down Due to LT line Cut	
12		Salkarpet SS	Jangamreddypally	11KV	Narayanapet	05.00	07.00	02.00		Break Down Due to Tree fallan down	
13		Salkarpet SS	Pagdiyial	11KV	Narayanapet	05.00	10.30	05.30		at HT/LT pole HT Line cut and fallen on LT line	
14		Salkarpet SS	Thala pump	11KV	Narayanapet	11.39	14.40	03.01		Break Down Due to Insulator failed	
15		Salkarpet SS	Pagdiyial	11KV	Narayanapet	12.00	15.00	03.00		Break Down Due to 11KV Insulator failed	-
16		Nancherla	Nancherla	11KV	Narayanapet	06.38	09.30	02.52		Break Down Due to 11KV conductor fallen down	-
17		Appakpally	Jajapur	11KV	Narayanapet	06.25	08.48	02.23		Tripped by EL due to heavy gail and rain	-
18		Mogulmadka	Annasagar	11KV	Narayanapet	09.00	10.00	01.00		Disc insulator fail at last pole on the feeder	-
19		Marikal	PC kunta	11KV	Narayanapet	04.15	08.32	04.17		Kasaram line back clamp cut and L-L fault	-
20		Uttoor	Nidugurthy	11KV	Narayanapet	08.31	08.45	00.14		Break Down Due to 11KV line cut	-
1	NLG	Athmakur(S)	Naseempet	11KV	Suryapet	02.40	06.50	04.10	E/L	11Kv Insulator flashover	-
2		Ananthagiri	Mogalaikota	11KV	Huzurnagar	08.00	10.15	02.15	E/L	11 KV LINE SNAPPED	-
3		Narketpally	Yadavelly	11KV	Nalgonda	11.00	11.30	00.30	E/L	11KV Jumper cut	-
4		Edulur	G.B.Gudem	11KV	Nalgonda	10.30	12.20	01.50	E/L	11KV Jumper cut	-
5		Settipalem	Settipalem-II	11KV	Miryalguda	07.55	11.30	03.35	E/L	11Kv Insulator flashover	-
6		Arror	Appareddypally	11KV	Choutuppal	00.10	09.10	09.00	EL/OL	11kv Disc Failed Appareddypally village.	-
1	MDK	Inole	Bayers Corp	11KV	Patancheru	06.20	11.03	04.43		BD due to Insulator Failed	-
2		Gummadidala	Agrobell	11KV	Patancheru	13.40	15.40	02.00		BD due to Tree branches fallen on line	-
3		Kistareddypet	Patelguda	11KV	Patancheru	12.30	14.03	01.33		BD due to Tree branches fallen on line	-
1	SDPT	Habshipur	Habshipur	11KV	Siddipet	02.18	06.00	03.42		B/D 11 kv disck failed	-
2		Chellapur	Chellapur	11KV	Siddipet	17.27	19.17	01.50		B/D 11 KV Insulater failed	-
3		Gonepally	Ramunipatla	11KV	Siddipet	17.43	17.58	00.15		B/D insuleter fail	-
4		Chandhapur	Gangapur	11KV	Siddipet	16.20	17.50	01.30		B/D 11 kv disck failed	-
5		Rajgopalpet	Mindrai	11KV	Siddipet	17.25	20.40	03.15		B/D insuleter fail	-
6		Ankshapur	Nagarajupally	11KV	Siddipet	07.49	10.10	02.21		B/D insuleter fail	-
7		Guruvannapet	Guruvannapet	11KV	Husnabad	14.20	16.05	01.45		Bird fallen in line	-
1	RR S	ESCI	Nanakramguda	11KV	Gachibowli	05.15	06.33	01.18	BD	11KV UG Cable failed at IBM Divyasri	-
1	RR N	Nizampet	Nizampet	11KV	Kukatpally	00.55	02.05	01.10	EL	Lizard fallen on the DTR opp water tank	-
2		Kompally	Kompally	11KV	Medchal	10.47	11.20	00.33	EL	11KV AB Cable problem at Balreddy House,Dulapally Road	-
3		Town Medchal	Balaji Nagar	11KV	Medchal	08.50	10.10	01.20	EL/OL	11KV Pole bend at Mallikarjuna Vencher	-
4		Kolthur	Anantharam	11KV	Medchal	16.15	17.25	01.10	EL/OL	Tree fallen on 11KV Line at Gajarat Thota	-
1	RR E	Singapurtownship	RGK	11KV	Keesara	20.10	22.35	02.25		11KV Pin insulator Failed at beside Sai Sandeep apartments Annojiguda	-
1	HYD N	Kalyan Nagar	Vengal Rao Nagar	11KV	Banjarahills	04.08	05.28	01.20	EL,OL-Rph	No Visible Fault	-
1	HYD S	Yakuthpura	Bada Bazar	11KV	Asmangadh	09.02	10.27	01.25	EL,OL-Rph	UG Cable fault at Bada Bazar (3No. DTR's kept off)	-
1	HYD C	Hussain Sagar	Fathe Maidan	11KV	Saifabad	22.20	23.25	01.05	EL,OL	Pin Insulator flash over at Fathe Sultan Lane	At 22:45Hrs partial fdr charged